



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0083 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: ABB

Manufacturer's Technical Representative: James Kluck, Product Manager

Mailing Address: PO Box 372, Milwaukee, WI 53201-0372

Telephone: (262) 785-3200 Email: james.e.kluck@us.abb.com

Product Information

Product Name: ACS550

Product Type: Variable Frequency Drives (VFDs)

Product Model Number: ACB530, ACH550, ACQ550, AYK550, ACS550

(List all unique product identification numbers and/or part numbers)

General Description: Wall and Floor Mounted Variable Frequency Drives that can control an AC motor with either VFD or Bypass.

Mounting Description: Rigid floor mounted; Rigid and flexible surfaced mounted on a wall.

Applicant Information

Applicant Company Name: The VMC Group

Contact Person: John P Giuliano, PE

Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: 973-838-1780 Email: john.giuliano@thevmcgroup.com


I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2013.

Signature of Applicant:  Date: _____

Title: President Company Name: The VMC Group

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY
OSH-FD-759 (REV 6/14/13)



osHPD

Page 1 of 3



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: The VMC Group

Name: Mr. Ken Tarlow California License Number: SE2851

Mailing Address: 980 9th Street, 16th Floor, Sacramento, CA 95814

Telephone: 916-449-9918 Email: ken.tarlow@thevmcgroup.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____

Testing Laboratory

Company Name: UC Berkeley

Contact Name: Wesley Neighbour

Mailing Address: 1301 South 46th Street, Building 420, Richmond, CA 94804

Telephone: 510-665-3409 Email: wdn@berkeley.com

Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dvnamic Needs





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 1.5 ($R_p=6.0$); 4.5 ($R_p=2.0$)

S_{DS} (Design spectral response acceleration at short period, g) = 2.0

a_p (In-structure equipment or component amplification factor) = 2.5

R_p (Equipment or component response modification factor) = 6.0 (rigid floor/wall mount); 2.0 (flexible wall mount)

Ω_0 (System overstrength factor) = 2.5

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See Attached Matrix

Overall dimensions and weight (or range thereof) = See Attached Matrix

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2010: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): _____

OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2019

Signature: *M. R. Karim*

Date: 4/16/2014

Print Name: M. R. Karim

Title: SHFR

Special Seismic Certification Valid Up to : S_{DS} (g) = 2.0

z/h = 1.0

Condition of Approval (if applicable): _____



Table 1 - Certified Drive Matrix

| System Voltage [V] | Model | Construction | ABB Model Number | Normal Duty Ratings | | Heavy Duty Ratings | | Frame Size | Max System Weight Type 12 [lbs] | Product Manufacturer | Mounting | Tested / Interpolated / Extrapolated |
|----------------------|--|--|------------------|---------------------|-----|--------------------|------|------------|-----------------------------------|----------------------|----------|--------------------------------------|
| | | | | Current [A] | HP | Current [A] | HP | | | | | |
| 208 / 240 | ACB530, ACH550, ACQ550, AYK550, ACS550 | -01, -UH, -U1, -U0 -OEMUx where OEM = any OEM code | ACx550-XX-04A6-2 | 4.6 | 1 | 3.5 | 0.75 | R1 | 18 | ABB | Wall | UUT 7A, UUT 7B |
| | | | ACx550-XX-06A6-2 | 6.6 | 1.5 | 4.6 | 1 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-07A5-2 | 7.5 | 2 | 6.6 | 1.5 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-012A-4 | 11.8 | 3 | 7.5 | 2 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-017-A2 | 16.7 | 5 | 11.8 | 3 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-024A-2 | 24.2 | 7.5 | 16.7 | 5 | R2 | 25 | ABB | Wall | Interpolated |
| | | | ACx550-XX-031A-2 | 30.8 | 10 | 24.2 | 7.5 | R2 | 25 | ABB | Wall | Interpolated |
| | | | ACx550-XX-046A-2 | 46.2 | 15 | 30.8 | 10 | R3 | 41 | ABB | Wall | Interpolated |
| | | | ACx550-XX-059A-2 | 59.4 | 20 | 46.2 | 15 | R3 | 41 | ABB | Wall | UUT 1A, UUT 1B |
| | | | ACx550-XX-075A-2 | 74.8 | 25 | 59.4 | 20 | R4 | 58 | ABB | Wall | Interpolated |
| | | | ACx550-XX-088A-2 | 88 | 30 | 74.8 | 25 | R4 | 58 | ABB | Wall | Interpolated |
| | | | ACx550-XX-114A-2 | 114 | 40 | 88 | 30 | R4 | 58 | ABB | Wall | Interpolated |
| | | | ACx550-XX-143A-2 | 143 | 50 | 114 | 40 | R6 | 190 | ABB | Wall | Interpolated |
| | | | ACx550-XX-178A-2 | 178 | 60 | 150 | 50 | R6 | 190 | ABB | Wall | Interpolated |
| ACx550-XX-221A-2 | 221 | 75 | 178 | 60 | R6 | 190 | ABB | Wall | Interpolated | | | |
| ACx550-XX-248A-2 | 248 | 100 | 192 | 75 | R6 | 190 | ABB | Wall | Interpolated | | | |
| 480 | ACB530, ACH550, ACQ550, AYK550, ACS550 | -01, -02, -UH, -U1, -U0 -OEMUx where OEM = any OEM code | ACx550-XX-03A3-4 | 3.3 | 1.5 | 2.4 | 1 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-04A1-4 | 4.1 | 2 | 3.3 | 1.5 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-06A9-4 | 6.9 | 3 | 5.4 | 2 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-08A8-4 | 8.8 | 5 | 6.9 | 3 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-012A-4 | 11.9 | 7.5 | 8.8 | 5 | R1 | 18 | ABB | Wall | Interpolated |
| | | | ACx550-XX-015A-4 | 15.4 | 10 | 11.9 | 7.5 | R2 | 25 | ABB | Wall | Interpolated |
| | | | ACx550-XX-023A-4 | 23 | 15 | 15.4 | 10 | R2 | 25 | ABB | Wall | Interpolated |
| | | | ACx550-XX-031A-4 | 31 | 20 | 23 | 15 | R3 | 41 | ABB | Wall | Interpolated |
| | | | ACx550-XX-038A-4 | 38 | 25 | 31 | 20 | R3 | 41 | ABB | Wall | Interpolated |
| | | | ACx550-XX-045A-4 | 44 | 30 | 38 | 25 | R3 | 41 | ABB | Wall | UUT 6A, UUT 6B |
| | | | ACx550-XX-059A-4 | 59 | 40 | 44 | 30 | R4 | 58 | ABB | Wall | Interpolated |
| | | | ACx550-XX-072A-4 | 72 | 50 | 59 | 40 | R4 | 58 | ABB | Wall | Interpolated |
| | | | ACx550-XX-078A-4 | 77 | 60 | 65 | 50 | R4 | 58 | ABB | Wall | Interpolated |
| | | | ACx550-XX-097A-4 | 96 | 75 | 77 | 60 | R4 | 58 | ABB | Wall | UUT 5A, UUT 5B |
| | | | ACx550-XX-125A-4 | 124 | 100 | 96 | 75 | R5 | 85 | ABB | Wall | Interpolated |
| | | | ACx550-XX-157A-4 | 157 | 125 | 124 | 100 | R6 | 190 | ABB | Wall | Interpolated |
| | | | ACx550-XX-180A-4 | 180 | 150 | 156 | 125 | R6 | 190 | ABB | Wall | Interpolated |
| | | | ACx550-XX-246A-4 | 245 | 200 | 192 | 150 | R6 | 190 | ABB | Wall | UUT 2A, UUT 2B |
| | | | ACx550-XX-316A-4 | 316 | 250 | 240 | 200 | R8 | 827 | ABB | Floor | UUT-3 |
| | | | ACx550-XX-368A-4 | 368 | 300 | 302 | 250 | R8 | 827 | ABB | Floor | Interpolated |
| ACx550-XX-414A-4 | 414 | 350 | 368 | 300 | R8 | 827 | ABB | Floor | Interpolated | | | |
| ACx550-XX-486A-4 | 486 | 400 | 414 | 350 | R8 | 827 | ABB | Floor | Interpolated | | | |
| ACx550-XX-526A-4 | 526 | 450 | 477 | 400 | R8 | 827 | ABB | Floor | Interpolated | | | |
| ACx550-XX-602A-4 | 602 | 500 | 515 | 450 | R8 | 827 | ABB | Floor | Interpolated | | | |
| ACx550-XX-645A-4 | 645 | 550 | 590 | 500 | R8 | 827 | ABB | Floor | UUT-4 | | | |

NOTE: Drive enclosures are installed inside NEMA 1, 12, or 3R cabinet (See Table 2)

01-Standard wall mount

UH-Same as U1 except SW for HVAC applications

02-PC version

U0-Same as U1/UH/01 except generic version to be mounted inside enclosure

U1-01 with US version SW (defaults to 60Hz and HP instead 50

OEMUx-OEM version of the ones listed above with OEM specific SW/configuration (addition of option modules where applicable)

Table 1 - Certified Drive Matrix (Continued)

| System Voltage [V] | Model | Construction | ABB Model Number | Normal Duty Ratings | | Heavy Duty Ratings | | Frame Size | Max System Weight Type 12 [lbs] | Product Manufacturer | Mounting | Tested / Interpolated / Extrapolated |
|-------------------------|--|---|---------------------|---------------------|-----|--------------------|-----|---------------|--|-------------------------|----------|--|
| | | | | Current [A] | HP | Current [A] | HP | | | | | |
| 600 | ACB530, ACH550, ACQ550, AYK550, ACS550 | -01, -UH, -U1, -OEMUx where OEM = any OEM code | ACx550-XX-02A7-6 | 2.7 | 2 | 2.4 | 1.5 | R2 | 25 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-03A9-6 | 3.9 | 3 | 2.7 | 2 | R2 | 25 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-06A1-6 | 6.1 | 5 | 3.9 | 3 | R2 | 25 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-09A0-6 | 9 | 7.5 | 6.1 | 5 | R2 | 25 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-011A-6 | 11 | 10 | 9 | 7.5 | R2 | 25 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-017A-6 | 17 | 15 | 11 | 10 | R2 | 25 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-022A-6 | 22 | 20 | 17 | 15 | R3 | 41 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-027A-6 | 27 | 25 | 22 | 20 | R3 | 41 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-032A-6 | 32 | 30 | 27 | 25 | R4 | 58 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-041A-6 | 41 | 40 | 32 | 30 | R4 | 58 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-052A-6 | 52 | 50 | 41 | 40 | R4 | 58 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-062A-6 | 62 | 60 | 52 | 50 | R4 | 58 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-077A-6 | 77 | 75 | 62 | 60 | R6 | 190 | ABB | Wall | Extrapolated |
| | | | ACx550-XX-099A-6 | 99 | 100 | 77 | 75 | R6 | 190 | ABB | Wall | Extrapolated |
| ACx550-XX-125A-6 | 125 | 125 | 99 | 100 | R6 | 190 | ABB | Wall | Extrapolated | | | |
| ACx550-XX-144A-6 | 144 | 150 | 125 | 125 | R6 | 190 | ABB | Wall | Extrapolated | | | |

NOTE: Drive enclosures are installed inside NEMA 1, 12, or 3R cabinet (See Table 2)

01-Standard wall mount
UH-Same as U1 except SW for HVAC applications

02-PC version
U0-Same as U1/UH/01 except generic
version to be mounted inside enclosure

U1-01 with US version SW (defaults to 60Hz and HP instead 50
OEMUx-OEM version of the ones listed above with OEM specific SW/configuration (addition
of option modules where applicable)

Table 2 - Certified Cabinet Matrix

| Cabinet ID | Drive Frame | Max Height [in] | Max Width [in] | Max Depth [in] | Max Cabinet Weight [lbs] | Type Rating | Panel Material / Thickness | Mounting Configuration | Product Manufacturer | Tested / Interpolated / Extrapolated |
|------------------------|-------------|-------------------|------------------|------------------|----------------------------|-------------|-----------------------------|------------------------|----------------------|--------------------------------------|
| VX1-1 | R1 | 40.2 | 5.4 | 10.1 | 32 | 1 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Extrapolated |
| PX1-1 PX12-1 | R1 | 29.3 | 8.7 | 11.2 | 37 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Extrapolated |
| VX1-2 | R2 | 44.1 | 5.4 | 10.3 | 40 | 1 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Extrapolated |
| PX1-2 PX12-2 | R2 | 33.2 | 8.7 | 11.6 | 46 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Extrapolated |
| VX1-3 | R2 / R3 | 47.7 | 8.4 | 10.9 | 70 | 1 | Carbon Steel / 1.5 mm Thick | Wall | ABB | UUT 1A, UUT 1B |
| BX1-1 BX12-1 | R1 | 33.2 | 17.4 | 13.5 | 78 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX1-3 PX12-3 | R3 | 40.6 | 10.5 | 11.9 | 79 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX1-2 BX12-2 | R2 | 33.2 | 17.4 | 13.5 | 84 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX1-3 BX12-3 | R2 | 33.2 | 17.4 | 13.5 | 84 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| VX1-4 | R4 | 51.8 | 8.4 | 12.1 | 92 | 1 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX1-4 PX12-4 | R4 | 45.8 | 10.5 | 13.1 | 99 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX1-3 BX12-3 | R3 | 37.4 | 20.5 | 15.3 | 120 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | UUT 6A, UUT 6B |
| PX3R-1 | R1 | 34 | 17.8 | 13.5 | 128 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | UUT 7A, UUT 7B |
| BX3R-1 | R1 | 34 | 17.8 | 13.5 | 128 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX3R-2 | R2 | 34 | 17.8 | 13.5 | 134 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX3R-2 | R2 | 34 | 17.8 | 13.5 | 134 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX1-4 BX12-4 | R4 | 37.4 | 20.5 | 15.3 | 138 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX3R-3 | R2 / R3 | 38.1 | 20.9 | 15.3 | 176 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX3R-3 | R2 | 38.1 | 20.9 | 15.3 | 176 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX3R-4 | R4 | 38.1 | 20.9 | 15.3 | 194 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX3R-4 | R4 | 38.1 | 20.9 | 15.3 | 194 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX3R-5 | R4 | 39 | 30 | 15.5 | 203 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX3R-5 | R4 | 39 | 30 | 15.5 | 213 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| PX1-5 PX12-5 | R4 / R5 | 54.3 | 28.1 | 19 | 267 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | UUT 5A, UUT 5B |
| BX1-5 BX12-5 | R4 | 54.3 | 28.1 | 19 | 267 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Interpolated |
| BX1-6 BX12-6 | R6 | 54.3 | 28.1 | 19 | 359 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | UUT 2A, UUT 2B |
| PX1-6 PX12-6 | R6 | 54.3 | 28.1 | 19 | 359 | 1 12 | Carbon Steel / 1.5 mm Thick | Wall | ABB | Extrapolated |
| BX3R-6 | R4 | 51 | 36 | 21.5 | 409 | 3R | Carbon Steel / 1.5 mm Thick | Wall | ABB | Extrapolated |
| PX1-8 PX12-8 | R8 | 93.6 | 31.7 | 25.9 | 1045 | 1 12 | Carbon Steel / 1.5 mm Thick | Floor | ABB | UUT-4 |
| BX1-8 BX12-8 | R8 | 83.7 | 31.7 | 25.9 | 838 | 1 12 | Carbon Steel / 1.5 mm Thick | Floor | ABB | UUT-3 |

Table 3 - Certified Fuses

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|--|---------------|--------------|-----------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 3AUA567999Z27 | FUSE,T DELAY, Transformer -Secondary fusing BC/BD (Type FNM) | 5-6/10A, 250V | < 0.2 | BUSSMANN COOPER | N/A | Extrapolated |
| 3AUA0000015604 | FUSE, CLASS CC, REJECTION | 15A, 600 V | < 0.2 | BUSSMANN COOPER | | UUT 7A, UUT 7B |
| 3AUA0000015605 | FUSE, CLASS CC, REJECTION | 30A, 600 V | < 0.2 | BUSSMANN COOPER | | Interpolated |
| 3AUA0000015606 | FUSE, CLASS T, REJECTION | 60A, 600 V | < 0.2 | BUSSMANN COOPER | | UUT 6A,UUT 6B |
| 3AUA0000015607 | FUSE, CLASS T, REJECTION | 100A, 600 V | < 0.2 | BUSSMANN COOPER | | UUT 1A, UUT 1B |
| 3AUA0000004429 | Drive Fuse, 170M1372, 315A | 315A | 0.3 | BUSSMANN COOPER | | UUT 2A, UUT 2B |
| 3AUA567002A23 | Drive Fuse, 170M1370, 200A | 200A | 0.3 | BUSSMANN COOPER | | Extrapolated |
| 64690647 | Drive Fuse | 400A | 0.5 | BUSSMANN COOPER | UUT 3 | N/A |
| 3AUA0000005225 | Drive Fuse | 600A | 1.0 | BUSSMANN COOPER | Interpolated | |
| 3AUA0000005226 | Drive Fuse | 800A | 1.7 | BUSSMANN COOPER | UUT 4 | |

Table 4 - Certified Terminal Blocks

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|----------------|--------|--------------|-----------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 3AUA0000025549 | Terminal Block | 85A | 0.2 | Curtis | N/A | UUT 6A, UUT 6B |
| 3AUA0000014810 | Terminal Block | 115A | 0.4 | BUSSMANN COOPER | | UUT 5A, UUT 5B |
| 3AUA266001B144 | Terminal Block | 175A | 0.4 | BUSSMANN COOPER | | UUT 1A, UUT 1B |

Table 5 - Certified Fans

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|--|-----------|--------------|-----------------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 3AUA0000000148 | Fan for top of bypass skeleton (B1 & B2 box) | 38-40 CFM | < 0.2 | NMB TECHNOLOGIES CORP | N/A | UUT 5A, UUT 5B |
| 3AUA0000012736 | For Cab & Drive skeleton | 38-40 CFM | < 0.2 | DELTA PRODUCTS CORP | | UUT 7A, UUT 7B |
| 3AUA0000012849 | BXR Cab only | 38-40 CFM | 0.4 | DELTA PRODUCTS CORP | | UUT 2A, UUT 2B |
| 3AUA648001B20 | FAN,ACS607,115V/60HZ | 718 CFM | 9.7 | DELTA PRODUCTS CORP | UUT 4 | N/A |

Table 6 - Certified Contactors

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|----------------------------|-------------|--------------|--------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 3AUA0000014843 | Contactora A9-30-10-84 | 9A / 21A | 0.7 | ABB | N/A | Extrapolated |
| 3AUA0000014844 | Contactora A12-30-10-84 | 11A / 25A | 0.7 | ABB | | Extrapolated |
| 3AUA0000014846 | Contactora A26-30-10-84 | 28A / 40A | 1.0 | ABB | | Extrapolated |
| 3AUA0000014857 | Contactora A30-30-10-84 | 34A / 50A | 1.2 | ABB | | UUT 6A, UUT 6B |
| 3AUA0000014847 | Contactora A40-30-10-84 | 42A / 60A | 2.3 | ABB | | UUT 6A, UUT 6B |
| 3AUA0000014848 | Contactora A50-30-00-84 | 45A / 80A | 2.3 | ABB | | UUT 1A, UUT 1B |
| 3AUA0000014850 | Contactora A75-30-00-84 | 80A / 105A | 2.3 | ABB | | UUT 1A, UUT 1B |
| 3AUA0000019449 | Contactora (A95-30-00-84) | 95A / 125A | 3.5 | ABB | | Interpolated |
| 3AUA0000019450 | Contactora (A110-30-00-84) | 110A / 140A | 5.0 | ABB | | Interpolated |
| 3AUA0000019451 | Contactora (A145-30-00-84) | 130A / 230A | 7.1 | ABB | | Interpolated |
| 3AUA0000019452 | Contactora (A185-30-00-84) | 156A / 250A | 7.1 | ABB | | UUT 2A, UUT 2B |
| 3AUA0000019453 | Contactora (A210-30-00-84) | 192A / 300A | 13.0 | ABB | | Interpolated |
| 3AUA0000019454 | Contactora (A260-30-00-84) | 248A / 350A | 13.0 | ABB | | UUT 2A, UUT 2B |
| 3AUA0000004886 | Contactora AF400-30-11-70 | 400A | 26.0 | ABB | | UUT 3 |
| 3AUA0000004888 | Contactora AF460-30-11-70 | 460A | 26.0 | ABB | UUT 3 | |

Table 7 - Certified Circuit Breakers

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | | |
|-----------------|----------------------------------|--------|--------------|--------------|------------------------|----------------|-----|
| | | | | | Floor | Wall | |
| 3AUA0000065223 | T1N025TL Circuit Breaker for PCR | 25A | 2.3 | ABB | N/A | UUT 7A, UUT 7B | |
| 3AUA0000065224 | T1N040TL Circuit Breaker for PCR | 40A | 2.3 | ABB | | Extrapolated | |
| 3AUA0000065225 | T1N080TL Circuit Breaker for PCR | 80A | 2.3 | ABB | | Extrapolated | |
| 3AUA0000065226 | T1N100TL Circuit Breaker for PCR | 100A | 2.3 | ABB | | Extrapolated | |
| 3AUA0000026218 | T2 Circuit Breaker(SACE) | 15A | 2.8 | ABB | | Extrapolated | |
| 3AUA0000026219 | T2 Circuit Breaker(SACE) | 40A | 2.8 | ABB | | Extrapolated | |
| 3AUA0000026220 | T2 Circuit Breaker(SACE) | 60A | 2.8 | ABB | | UUT 6A, UUT 6B | |
| 3AUA0000026221 | T2 Circuit Breaker(SACE) | 100A | 2.8 | ABB | | UUT 1A, UUT 1B | |
| 3AUA0000019628 | T4 Circuit Breaker, T4N150E5W | 150A | 6.2 | ABB | | UUT 5A, UUT 5B | |
| 3AUA0000019629 | T4 Circuit Breaker, T4N250E5W | 250A | 6.2 | ABB | | Interpolated | |
| 3AUA0000019630 | T5 Circuit Breaker, T5N400E5W | 400A | 8.6 | ABB | | UUT 2A, UUT 2B | |
| 3AUA0000108996 | Circuit Breaker-TypeS T6S600E5W | 600A | 20.9 | ABB | | UUT 3 | N/A |
| 3AUA0000108997 | Circuit Breaker-TypeS T6S800E5W | 800A | 20.9 | ABB | | UUT 4 | |
| 3AUA0000108998 | Circuit Breaker-TypeH T6H800E5W | 600A | 20.9 | ABB | | Extrapolated | |

Table 8 - Certified Fuse Blocks

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|--------------------------------------|---------------|--------------|-----------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 3AUA0000031820 | Fuse block, mount in enclosure frame | 30A, 600 V | 0.2 | MERSEN USA | N/A | UUT 7A, UUT 7B |
| 3AUA0000016636 | Fuse Block, 3P, class T | 31-60A, 600 V | 0.5 | BUSSMANN COOPER | | UUT 6A, UUT 6B |
| BG56790001-4 | Fuse block, mount in enclosure frame | 60A, 600 V | 0.5 | BUSSMANN COOPER | | Interpolated |
| 3AUA567003A59 | Drive Fuse Holder 400A | 400A, 1000 V | 0.7 | BUSSMANN COOPER | | UUT 2A, UUT 2B |
| 3AUA567003A95 | Fuse Block, 3P, class T | 100A, 600 V | 1.0 | BUSSMANN COOPER | | UUT 1A, UUT 2B |

Table 9a - Certified Transformers

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|------------------------------------|----------------------|--------------|-----------------------------|------------------------|--------------|
| | | | | | Floor | Wall |
| BG56720008-9 | Transformer -Primary fusing BC/BD | 3A 600V | < 0.2 | BUSSMANN COOPER | N/A | UUT7A, UUT7B |
| 3AUA0000019997 | Transformer for control and/or fan | 500VA, 380-500V/115V | 15.0 | HAMMOND POWER SOLUTIONS INC | UUT 4 | N/A |

Table 9b - Certified Transformers

| ABB Part Number | Coil Material |
|-----------------|---------------|
| BG56720008-9 | Copper |
| 3AUA0000019997 | |

Table 10 - Certified Disconnect Switches

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|-------------------|--------|--------------|--------------|------------------------|-------------------------------|
| | | | | | Floor | Wall |
| 3AUA0000049775 | Disconnect Switch | 40A | 0.2 | ABB | N/A | UUT 7A, UUT 7B |
| 3AUA0000049774 | Disconnect Switch | 63A | 0.6 | ABB | | Interpolated |
| 3AUA0000049776 | Disconnect Switch | 80A | 0.6 | ABB | | UUT1A, UUT 1B, UUT 6A, UUT 6B |
| 3AUA0000049777 | Disconnect Switch | 100A | 0.8 | ABB | | Interpolated |
| 3AUA0000016618 | Disconnect Switch | 125A | 2.4 | ABB | | Interpolated |
| 3AUA0000019627 | Disconnect Switch | 200A | 1.2 | ABB | | Interpolated |
| 3AUA0000019631 | Disconnect Switch | 400A | 8.6 | ABB | | UUT 2A, UUT 2B |
| 3AUA0000014729 | Disconnect Switch | 800A | 20.9 | ABB | UUT 4 | N/A |
| 3AUA0000109909 | Disconnect Switch | 800A | 20.9 | ABB | UUT 4 | |

Table 11 - Certified Filters

| ABB Part Number | Description | Rating or Material | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|----------------------------------|--------------------|--------------|--------------|------------------------|-------------------------------|
| | | | | | Floor | Wall |
| 3AUA0000004887 | Filter, Air Precut 150x300xx12.5 | polyester/plastic | < 0.2 | Tex Air | N/A | UUT 2A, UUT 2B, UUT5A, UUT 5B |
| 3AUA0000006722 | FILTER, 500MM UL TYPE 12 | polyester/plastic | < 0.2 | Tex Air | UUT 4 | N/A |
| 3AUA0000006723 | FILTER MATERIAL-MAIN DOORS, R7-8 | polyester/plastic | < 0.2 | Tex Air | UUT 4 | N/A |

Table 12 - Certified Current Transducers

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|--------------------------|--------|--------------|--------------|------------------------|--------------------------------|
| | | | | | Floor | Wall |
| 3AUA0000014759 | Current Transformer (CT) | 25A | 0.4 | ABB | N/A | UUT 7A, UUT 7B |
| 3AUA0000014760 | Current Transformer (CT) | 75A | 0.4 | ABB | | UUT 1A, UUT 1B, UUT 6A, UUT 6B |
| 3AUA0000004443 | Current Transformer (CT) | 300:5 | 0.4 | AMRAN INC | | Extrapolated |
| 3AUA476001B24 | Current Transformer (CT) | 200:5 | 0.4 | AMRAN INC | | UUT 5A, UUT 5B |
| 3AUA476001B25 | Current Transformer (CT) | 500:5 | 1.0 | AMRAN INC | UUT 3, UUT 4 | UUT 2A, UUT 2B |

Table 13 - Certified Service Switches - Type Code +F267

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|-------------------------------------|--------|--------------|--------------|------------------------|--------------------------------|
| | | | | | Floor | Wall |
| 3AUA0000049775 | Disconnect Switch P B&V | 40A | 0.2 | ABB | N/A | UUT 7A, UUT 7B |
| 3AUA0000049776 | Disconnect Switch P B&V | 80A | 0.6 | ABB | | UUT 1A, UUT 1B, UUT 6A, UUT 6B |
| 3AUA0000049777 | Disconnect Switch P B&V | 100A | 0.8 | ABB | | Interpolated |
| 3AUA0000016618 | Disconnect Switch P B&V | 125A | 2.4 | ABB | | Interpolated |
| 3AUA0000014378 | Service Switch, T3S225DW | 225A | 5.5 | ABB | | Interpolated |
| 3AUA0000019631 | Disconnect Molded Case CB, T5H400DW | 400A | 8.6 | ABB | | UUT 2A, UUT 2B |
| 3AUA0000109909 | Disconnect Switch-TypeDW T6H800DW | 800A | 20.9 | ABB | UUT 3 | N/A |

Table 14 - Certified Reactors - Type Code +E213

| ABB Part Number | Description | Rating | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|--|-------------------------|--------------|-----------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 3AUA266001B144 | Terminal block to plate, BX | 3 pole, 175A | 0.4 | BUSSMANN COOPER | N/A | UUT 5A, UUT 5B |
| 68587344 | Line Reactor, Choke | 290/220 UH, 125 A | < 0.2 | ABB | | UUT 7A, UUT 7B |
| 3AUA0000008409 | For new 230V Line Reactor | 230Volts at 240Joules | 0.4 | ABB | | Interpolated |
| 3AUA0000008410 | For new 480V Line Reactor | 480Volts at 470Joules | 0.4 | ABB | | Interpolated |
| 3AUA0000008411 | For new 600V Line Reactor | 600 Volts at 300 Joules | 0.4 | ABB | | Interpolated |
| 3AUA0000015536 | AC line reactor R1 1.2mH,12A continuous-NEW TYPE 12 | 1.2mH, 12A | 5.4 | ABB | | UUT 7A, UUT 7B |
| 3AUA0000015537 | AC line reactor R2 0.42mH,31A continuous-NEW TYPE 12 | 0.42mH, 31A | 6.6 | ABB | | Interpolated |
| 3AUA0000015538 | AC line reactor R3 0.33mH,59A continuous-NEW TYPE 12 | 0.33mH, 59A | 15.8 | ABB | | UUT 6A, UUT 6B |
| 3AUA0000015539 | AC line reactor R4 0.18mH,75A continuous-NEW TYPE 12 | 0.18mH, 75A | 16.0 | ABB | | Extrapolated |

Table 15 - Certified Options

| ABB Part Number | Description | Type Code | Weight (Lbs) | Manufacturer | Mounting Configuration | |
|-----------------|-------------------------------------|-----------|--------------|--------------|------------------------|----------------|
| | | | | | Floor | Wall |
| 64606891 | DeviceNet (non-byp only) | K451 | < 0.2 | ABB | Extrapolated | Extrapolated |
| 68469341 | DeviceNet Redwood | K451 | < 0.2 | ABB | Extrapolated | UUT 1A, UUT 1B |
| 3AUA0000037539 | Lonworks Redwood | K452 | < 0.2 | ABB | Extrapolated | Interpolated |
| 64606883 | Lonworks | K452 | < 0.2 | ABB | UUT 4 | Interpolated |
| 64606859 | Profibus(non-byp only) | K454 | < 0.2 | ABB | Interpolated | UUT 5A, UUT 5B |
| 68469325 | Profibus Redwood | K454 | < 0.2 | ABB | Interpolated | Interpolated |
| 64751727 | ACH Software RETA New(non-byp only) | K466 | < 0.2 | ABB | UUT 4 | UUT 7A, UUT 7B |
| 68469422 | ACH Software FENA New | K466 | < 0.2 | ABB | UUT 3 | Interpolated |
| 3AUA0000002051 | Pulse Encoder for UH & PX only | L502 | < 0.2 | ABB | Extrapolated | UUT 5A, UUT 5B |
| 3AUA0000002040 | Relay Output Extension | L511 | < 0.2 | ABB | Extrapolated | UUT 1A, UUT 1B |
| 3AUA0000003489 | 115/230V input (non-byp only) | L512 | < 0.2 | ABB | Extrapolated | UUT6A, UUT6B |
| 64751701 | RCNA-01 Software Kit | K462 | < 0.2 | ABB | Software only | |
| 68840830 | ACS/H Software RETA-02 New | K467 | < 0.2 | ABB | Software only | |

UUT-01A

Manufacturer: ABB
Model Series: ACH550-VCR-059-2
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 10.9 | 8.4 | 47.7 | 70.0 | N/A | N/A | N/A |
| Fuse, 100A,600V | | | | | | | |
| Terminal Block, 75A | | | | | | | |
| Contactors, 45A/80A, 80A/105A | | | | | | | |
| Circuit Breaker, 100A | | | | | | | |
| Fuse Block, 100A,600V | | | | | | | |
| Disconnect Switch, 80A | | | | | | | |
| Current Transducer, 75A | | | | | | | |
| Service Switch, 80A | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-01A was wall-mounted to the fixture using qty (4) 1/4" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was rigidly mounted to the base plates using qty (6) 1" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-01B

Manufacturer: ABB
Model Series: ACH550-VCR-059-2
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 10.9 | 8.4 | 47.7 | 70.0 | N/A | N/A | N/A |
| Fuse, 100A,600V | | | | | | | |
| Terminal Block, 75A | | | | | | | |
| Contactors, 45A/80A, 80A/105A | | | | | | | |
| Circuit Breaker, 100A | | | | | | | |
| Fuse Block, 100A,600V | | | | | | | |
| Disconnect Switch, 80A | | | | | | | |
| Current Transducer, 75A | | | | | | | |
| Service Switch, 80A | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-01B was wall-mounted to the fixture using qty (4) 1/4" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was mounted on qty (6) VMC-Manufactured MSSH-1E spring isolators using each mount's 3/4" diameter adjusting bolt. Each isolator was attached to the base plate using qty (4) 3/4" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-02A

Manufacturer: ABB
Model Series: ACH550-BCR-246A-4
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:


| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 19.0 | 28.1 | 54.3 | 359.0 | N/A | N/A | N/A |
| Fuse, 315A | | | | | | | |
| Fan, 38-40 CFM | | | | | | | |
| Contactors, 156A/250A, 248A/350A | | | | | | | |
| Circuit Breaker, 400A | | | | | | | |
| Fuse Block, 400A,1000V | | | | | | | |
| Disconnect Switch, 400A | | | | | | | |
| Filter | | | | | | | |
| Current Transducer, 500:5 | | | | | | | |
| Service Switch, 400A | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-02A was wall-mounted to the fixture using qty (4) 3/8" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was rigidly mounted to the base plates using qty (6) 1" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-02B

| | |
|--------------------------------------|--------------------|
| Manufacturer: | ABB |
| Model Series: | ACH550-BCR-246A-4 |
| Cabinet Construction Summary: | 16 GA Carbon Steel |
| Wall Configuration Summary: | 16 GA Carbon Steel |


| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 19.0 | 28.1 | 54.3 | 359.0 | N/A | N/A | N/A |
| Fuse, 315A | | | | | | | |
| Fan, 38-40 CFM | | | | | | | |
| Contactors, 156A/250A, 248A/350A | | | | | | | |
| Circuit Breaker, 400A | | | | | | | |
| Fuse Block, 400A,1000V | | | | | | | |
| Disconnect Switch, 400A | | | | | | | |
| Filter | | | | | | | |
| Current Transducer, 500:5 | | | | | | | |
| Service Switch, 400A | | | | | | | |

| Seismic Test Parameters: | | | | | | | |
|---------------------------------|------|-----|-----|--------|--------|--------|--------|
| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed

Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-02B was wall-mounted to the fixture using qty (4) 3/8" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was mounted on qty (6) VMC-Manufactured MSSH-1E spring isolators using each mount's 3/4" diameter adjusting bolt. Each isolator was attached to the base plate using qty (4) 3/4" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-03

Manufacturer: ABB
Model Series: ACH550-BCR-316A-4
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 25.9 | 31.7 | 83.7 | 838.0 | 8.9 | 8.3 | N/A |
| Fuse, 400A | | | | | | | |
| Contactors, 400A/460A | | | | | | | |
| Circuit Breaker, 600A | | | | | | | |
| Current Transducer, 500:5 | | | | | | | |
| Service Switch, 800A | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-3 was floor-mounted to the base plate using qty (4) 1/2" Grade 8 bolts in the manufacturer-provided holes. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-04

| | |
|--------------------------------------|--------------------|
| Manufacturer: | ABB |
| Model Series: | ACH550-PCR-645A-4 |
| Cabinet Construction Summary: | 16 GA Carbon Steel |
| Wall Configuration Summary: | 16 GA Carbon Steel |


| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 25.9 | 31.7 | 93.6 | 1045.0 | 6.6 | 7.2 | N/A |
| Fuse, 800A | | | | | | | |
| Fan, 718 CFM | | | | | | | |
| Circuit Breaker, 800A | | | | | | | |
| Transformer, 500VA,380-500V/115V | | | | | | | |
| Disconnect Switch, 800A | | | | | | | |
| Filter | | | | | | | |
| Current Transducer, 500:5 | | | | | | | |
| | | | | | | | |

| Seismic Test Parameters: | | | | | | | |
|---------------------------------|------|-----|-----|--------|--------|--------|--------|
| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed

Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-4 was floor-mounted to the base plate using qty (4) 1/2" Grade 8 bolts in the manufacturer-provided holes. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-05A

Manufacturer: ABB
Model Series: ACH550-PCR-097A-4
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 19.0 | 28.1 | 54.3 | 267.0 | N/A | N/A | N/A |
| Terminal Block, 115A | | | | | | | |
| Fan, 38-40 CFM | | | | | | | |
| Circuit Breaker, 150A | | | | | | | |
| Filter | | | | | | | |
| Current Transducer, 200:5 | | | | | | | |
| Reactor, 3 pole, 175A | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-05A was wall-mounted to the fixture using qty (4) 1/4" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was rigidly mounted to the base plates using qty (6) 1" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-05B

Manufacturer: ABB
Model Series: ACH550-PCR-097A-4
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 19.0 | 28.1 | 54.3 | 267.0 | N/A | N/A | N/A |
| Terminal Block, 115A | | | | | | | |
| Fan, 38-40 CFM | | | | | | | |
| Circuit Breaker, 150A | | | | | | | |
| Filter | | | | | | | |
| Current Transducer, 200:5 | | | | | | | |
| Reactor, 3 pole, 175A | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:
 UUT-05B was wall-mounted to the fixture using qty (4) 1/4" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was mounted on qty (6) VMC-Manufactured MSSH-1E spring isolators using each mount's 3/4" diameter adjusting bolt. Each isolator was attached to the base plate using qty (4) 3/4" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".



UUT-06A

Manufacturer: ABB
Model Series: ACH550-BCR-045A-A
Cabinet Construction Summary: 16 GA Carbon Steel
Wall Configuration Summary: 16 GA Carbon Steel

Component Summary:

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 15.3 | 20.5 | 37.4 | 120.0 | N/A | N/A | N/A |
| Fuse, 60A,600V | | | | | | | |
| Terminal Block, 85A | | | | | | | |
| Contact, 34A/50A; 42A/60A | | | | | | | |
| Circuit Breaker, 60A | | | | | | | |
| Fuse Block, 31-60A, 600V | | | | | | | |
| Disconnect Switch, 80A | | | | | | | |
| Current Transducer, 75A | | | | | | | |
| Service Switch, 80A | | | | | | | |
| Reactor, 0.33mH, 59A | | | | | | | |

Seismic Test Parameters:

| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
|----------------------|------|-----|-----|--------|--------|--------|--------|
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed
 Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-06A was wall-mounted to the fixture using qty (4) 3/8" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was rigidly mounted to the base plates using qty (6) 1" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-06B

| | |
|--------------------------------------|--------------------|
| Manufacturer: | ABB |
| Model Series: | ACH550-BCR-045A-A |
| Cabinet Construction Summary: | 16 GA Carbon Steel |
| Wall Configuration Summary: | 16 GA Carbon Steel |

| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 15.3 | 20.5 | 37.4 | 120.0 | N/A | N/A | N/A |
| Fuse, 60A,600V | | | | | | | |
| Terminal Block, 85A | | | | | | | |
| Contact, 34A/50A; 42A/60A | | | | | | | |
| Circuit Breaker, 60A | | | | | | | |
| Fuse Block, 31-60A, 600V | | | | | | | |
| Disconnect Switch, 80A | | | | | | | |
| Current Transducer, 75A | | | | | | | |
| Service Switch, 80A | | | | | | | |
| Reactor, 0.33mH, 59A | | | | | | | |

| Seismic Test Parameters: | | | | | | | |
|---------------------------------|------|-----|-----|--------|--------|--------|--------|
| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed

Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-06B was wall-mounted to the fixture using qty (4) 3/8" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was mounted on qty (6) VMC-Manufactured MSSH-1E spring isolators using each mount's 3/4" diameter adjusting bolt. Each isolator was attached to the base plate using qty (4) 3/4" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-07A

| | |
|--------------------------------------|--------------------|
| Manufacturer: | ABB |
| Model Series: | ACH550-PDR-04A6-2 |
| Cabinet Construction Summary: | 16 GA Carbon Steel |
| Wall Configuration Summary: | 16 GA Carbon Steel |


| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 13.5 | 17.8 | 34.0 | 128.0 | N/A | N/A | N/A |
| Fuse, 15A,600V | | | | | | | |
| Fan, 38-40 CFM | | | | | | | |
| Fuse Block, 30A, 600V | | | | | | | |
| Transformer, 3A,600V | | | | | | | |
| Disconnect Switch, 40A | | | | | | | |
| Current Transducer, 25A | | | | | | | |
| Service Switch, 40A | | | | | | | |
| Reactor, 290/220 UH, 125A; 1.2mH, 12A | | | | | | | |

| Seismic Test Parameters: | | | | | | | |
|---------------------------------|------|-----|-----|--------|--------|--------|--------|
| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed

Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-07A was wall-mounted to the fixture using qty (4) 3/8" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was rigidly mounted to the base plates using qty (6) 1" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".

UUT-07B

| | |
|--------------------------------------|--------------------|
| Manufacturer: | ABB |
| Model Series: | ACH550-PDR-04A6-2 |
| Cabinet Construction Summary: | 16 GA Carbon Steel |
| Wall Configuration Summary: | 16 GA Carbon Steel |


| Item | Dimensions | | | | Lowest Nat. Freq. | | |
|--|------------|------------|-------------|-------------|-------------------|----------|--------|
| | Depth (in) | Width (in) | Height (in) | Weight (lb) | F-B (Hz) | S-S (Hz) | V (Hz) |
| Cabinet (Weight Listed is for Package) | 13.5 | 17.8 | 34.0 | 128.0 | N/A | N/A | N/A |
| Fuse, 15A,600V | | | | | | | |
| Fan, 38-40 CFM | | | | | | | |
| Fuse Block, 30A, 600V | | | | | | | |
| Transformer, 3A,600V | | | | | | | |
| Disconnect Switch, 40A | | | | | | | |
| Current Transducer, 25A | | | | | | | |
| Service Switch, 40A | | | | | | | |
| Reactor, 290/220 UH, 125A; 1.2mH, 12A | | | | | | | |

| Seismic Test Parameters: | | | | | | | |
|---------------------------------|------|-----|-----|--------|--------|--------|--------|
| Qualification Method | Sds | z/h | Ip | Aflx-H | Arig-H | Aflx-V | Arig-V |
| ICC-ES AC156 | 2.00 | 1.0 | 1.5 | 3.2 | 2.4 | 1.33 | 0.53 |

Pre/Post Shake Functionality Test Results:

Pre: Passed

Post: Passed: All units were filled with contents and maintained structural integrity and functionality



UUT Mounting Description:

UUT-07B was wall-mounted to the fixture using qty (4) 3/8" Grade 8 bolts in the manufacturer-provided holes. The wall fixture was mounted on qty (6) VMC-Manufactured MSSH-1E spring isolators using each mount's 3/4" diameter adjusting bolt. Each isolator was attached to the base plate using qty (4) 3/4" Grade 8 bolts. The base plate was attached to the shake table using qty (9) high-strength rods with a minimum diameter of 1".