



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: **OSP – 0391 – 10**

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: Daikin Applied

Manufacturer's Technical Representative: Zach Morris

Mailing Address: 207 Laurel Hill Road, Verona, VA 24482

Telephone: (540) 248-9516 Email: Zach.moris@daikinapplied.com

Product Information

Product Name: AGZ Trailblazer

Product Type: Air-Cooled Scroll Compressor Chiller

Product Model Number: AGZ030E through AGZ241E and AGZ075D through AGZ130D
(List all unique product identification numbers and/or part numbers)

General Description: Outdoor Air-Cooled Scroll Compressor Chiller. Seismic enhancements made to the test units & modifications required to address the anomalies observed during testing shall be incorporated into the production units

Mounting Description: Base mounted neoprene or spring isolated

Applicant Information

Applicant Company Name: Structural Integrity Associates, Inc. dba TRU Compliance

Contact Person: Andrew Coughlin, SE

Mailing Address: 5215 Hellyer Ave, Suite 210, San Jose, CA 94608

Telephone: (844) 878-0200 Email: acoughlin@structint.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 12/21/2017

Title: Director, TRU Compliance Company Name: Structural Integrity Associates, Inc.

Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: Structural Integrity Associates, Inc. dba TRU Compliance

Name: Andrew Coughlin, SE California License Number: S6082

Mailing Address: 5215 Hellyer Ave, Suite 210, San Jose, CA 94608

Telephone: (844) 878-0200 Email: acoughlin@structint.com

Supports and Attachments Preapproval

- Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

Certification Method

- Testing in accordance with: ICC-ES AC156
- Other (Please Specify): _____

Testing Laboratory

Company Name: U.S. Army Engineer Research and Development Center, Construction Engineering Research Laboratory (ERDC-CERL)

Contact Name: Jim Wilcoski

Mailing Address: 2902 Newmark Dr. Champaign, IL 61822

Telephone: (217) 373-6763 Email: James.wilcoski@usace.army.mil

Company Name: Dynamic Certification Laboratories

Contact Name: Dr. Ahmad Itani, SE

Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431

Telephone: (775) 358-5085 Email: erinne@shaketest.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = See Attachment

S_{DS} (Design spectral response acceleration at short period, g) = See Attachment

a_p (In-structure equipment or component amplification factor) = 2.5

R_p (Equipment or component response modification factor) = 2.5 (Neoprene Isolated) & 2.0 (Spring Isolated)

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = See Attachment

Equipment or Component Natural Frequencies (Hz) = See Attachment

Overall dimensions and weight (or range thereof) = See Attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____


Tank(s) designed in accordance with ASME BPVC, 2015: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): Product and Subcomponent Matrices, UUT Summaries


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022

Signature:  Date: February 26, 2018

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to : S_{DS} (g) = See Above z/h = See Above

Condition of Approval (if applicable): _____



SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 1700737



Manufacturer: Daikin Applied	TABLE 1
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	

Certified Product Construction Summary:
Powder-coated carbon steel base and frame with seismic cross bracing

Certified Options Summary:
208-230V or 460V, controller, condenser fans, motors, condenser coils, hermetic scroll compressors, and brazed plate evaporators

Mounting Configuration:
Base mounted - neoprene or spring isolated
Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016 **Seismic Certification Limits:** $S_{DS} = 2.0 g$ $z/h = 1.0$ $F_p/W_p = 3.60$ (Neoprene), 4.50(Spring) $I_p = 1.5$

Model Line	Model	Dimensions (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
Trailblazer Air-Cooled Scroll Compressor Chillers "E" Vintage	AGZ030E	88	94.3	100.2	2960	4 fan	1
	AGZ035E	88	94.3	100.2	2887	4 fan	Interp.
	AGZ040E	88	94.3	100.2	2964	4 fan	Interp.
	AGZ045E	88	94.3	100.2	3112	4 fan	Interp.
	AGZ050E	88	94.3	100.2	3114	4 fan	Interp.
	AGZ055E	88	94.3	100.2	3128	4 fan	Interp.
	AGZ060E	88	94.3	100.2	3155	4 fan	Interp.
	AGZ065E	88	94.3	100.2	3155	4 fan	Interp.
Trailblazer Air-Cooled Scroll Compressor Chillers "D" Vintage	AGZ070E	88	94.3	100.2	3497	4 fan	2
	AGZ075D	88	134.9	100.4	5350	6 fan	Interp.
	AGZ080D	88	134.9	100.4	5385	6 fan	Interp.
	AGZ090D	88	134.9	100.4	5420	6 fan	Interp.
	AGZ100D	88	134.9	100.4	5675	6 fan	Interp.
	AGZ110D	88	173.1	100.4	6340	6 fan	Interp.
	AGZ125D	88	173.1	100.4	6475	8 fan	Interp.
	AGZ130D	88	173.1	100.4	6520	8 fan	3

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 1700737



Manufacturer: Daikin Applied	TABLE 2
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	

Certified Product Construction Summary:
Powder-coated carbon steel base and frame with seismic cross bracing

Certified Options Summary:
208-230V or 460V, controller, condenser fans, motors, condenser coils, hermetic scroll compressors, and brazed plate evaporators

Mounting Configuration:
Base mounted - neoprene or spring isolated
Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016
Seismic Certification Limits: $S_{DS} = 0.63 g$ $z/h = 1.0$ $F_p/W_p = 1.13$ (Neoprene), 1.42 (Spring) $I_p = 1.5$
 $S_{DS} = 0.79 g$ $z/h = 0.0$ $F_p/W_p = 0.47$ (Neoprene), 0.59 (Spring)

Model Line	Model	Dimensions (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
Trailblazer Air-Cooled Scroll Compressor Chillers "E" Vintage	AGZ075E	88	147	98.6	4451	6 fan, UUT2 is lower bound	Interp.
	AGZ080E	88	147	98.6	4579	6 fan	Interp.
	AGZ090E	88	147	98.6	4609	6 fan	Interp.
	AGZ100E	88	147	98.6	4780	6 fan	Interp.
	AGZ110E	88	192.1	98.6	5528	8 fan	Interp.
	AGZ120E	88	192.1	98.6	5796	8 fan	Interp.
	AGZ130E	88	192.1	98.6	5903	8 fan	Interp.
	AGZ140E	88	237.2	98.6	6674	10 fan	Interp.
	AGZ150E	88	237.2	98.6	6745	10 fan	Interp.
	AGZ160E	88	237.2	98.6	6802	10 fan	Interp.
	AGZ161E	88	237.2	98.6	7065	10 fan	Interp.
	AGZ170E	88	237.2	98.6	7307	10 fan	Interp.
	AGZ180E	88	237.2	98.6	7560	10 fan	Interp.
	AGZ191E	88	282.3	98.6	8785	12 fan	Interp.
	AGZ211E	88	282.3	98.6	8819	12 fan	Interp.
	AGZ226E	88	327.4	98.6	9600	14 fan	Interp.
AGZ241E	88	327.4	98.6	9688	14 fan	4	

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 1700737



Manufacturer: Daikin Applied	TABLE 3
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	

Building Code: CBC 2016 **Seismic Certification Limits:** $S_{DS} = 2.0g$ $z/h = 1.0$ $F_p/W_p = 3.60$ (Neoprene), 4.50(Spring) $I_p = 1.5$

Component Type	Manufacturer	Model	Description	Notes	UUT
Control Panel	Siemens	POL687.70/MCQ 460V	MicroTech III, 10"x72"x40" (DxWxH)	NEMA 1, Painted Galvanized CS	1
		POL687.70/MCQ 208-230V	MicroTech III, 10"x72"x40" (DxWxH)	NEMA 1, Painted Galvanized CS	2,3
Condenser Fans	Hess Air	HAP-9001174	30" dia, 4 Blades, 28 deg Pitch, 5 lbs	Al Blade/SS Hub	1
		HAP-9001132	30" dia, 4 Blades, 33 deg Pitch, 5 lbs		2,3
Fan Motors	Marathon	5K49ZN6302S	208-230V, 3-Phase, 1.5 HP	CS Housing	1
		5K49ZN6301S	460V, 3-Phase, 2 HP	CS Housing	2
		5K49ZN6270BS	460V, 3-Phase, 2 HP	CS Housing	3
Condenser Coils	Sanhua	X1470023	Microchannel	Galvanized CS Case, Al Channels	2
	Daikin	020889500200C2R01	Tube and Fin	Galvanized CS, Cu Tubes, Al Fins	1
	Daikin	022021000100C1R01	Tube and Fin	Galvanized CS, Cu Tubes, Al Fins	3
Scroll Compressor	Copeland	ZP90KCE	7.5 HP, Tandem or Trio Config.	CS Shell, Tandem Config. Tested	1
		ZP104KCE	9 HP, Tandem or Trio Config.	CS Shell	Interp.
		ZP122KCE	10 HP, Tandem or Trio Config.	CS Shell	Interp.
		ZP137KCE	12 HP, Tandem or Trio Config.	CS Shell	Interp.
		ZP154KCE	13 HP, Tandem or Trio Config.	CS Shell	Interp.
		ZP182KCE	15 HP, Tandem or Trio Config.	CS Shell, Tandem Config. Tested	2
		ZP236KCE	20 HP, Tandem or Trio Config.	CS Shell, Tandem Config. Tested	2
		ZP296KCE	25 HP, Tandem or Trio Config.	CS Shell, Trio Config. Tested	3

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 1700737



Manufacturer: Daikin Applied	TABLE 3
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	

Building Code: CBC 2016 **Seismic Certification Limits:** $S_{DS} = 2.0g$ $z/h = 1.0$ $F_p/W_p = 3.60$ (Neoprene), 4.50(Spring) $I_p = 1.5$

Component Type	Manufacturer	Model	Description	Notes	UUT
Evaporators	Alfa Laval	ACH230DQ-78	SS Plate Brazed with Cu		1
		ACH230DQ-86	SS Plate Brazed with Cu		Interp.
		ACH230DQ-94	SS Plate Brazed with Cu		Interp.
		ACH230DQ-110	SS Plate Brazed with Cu		Interp.
		ACH230DQ-126	SS Plate Brazed with Cu		Interp.
		ACH230DQ-134	SS Plate Brazed with Cu		Interp.
		ACH230DQ-154	SS Plate Brazed with Cu		2
		ACH500DQ-94	SS Plate Brazed with Cu		Interp.
		ACH500DQ-106	SS Plate Brazed with Cu		Interp.
		ACH500DQ-114	SS Plate Brazed with Cu		Interp.
		ACH500DQ-134	SS Plate Brazed with Cu		Interp.
		ACH500DQ-142	SS Plate Brazed with Cu		Interp.
		ACH500DQ-162	SS Plate Brazed with Cu		Interp.
		ACH500DQ-182	SS Plate Brazed with Cu		3
Expansion Valves	Sporlan	OZE-20-N-BP15	20 tons Nominal	Brass Bar Body w/ Cu Tubing	1
		OZE-25-N-BP15	25 tons Nominal	Brass Bar Body w/ Cu Tubing	Interp.
		OZE-35-N-BP15	35 tons Nominal	Brass Bar Body w/ Cu Tubing	2
		OZE-50-N-BP15	50 tons Nominal	Brass Bar Body w/ Cu Tubing	Interp.
		OZE-60-N-BP15	60 tons Nominal	Brass Bar Body w/ Cu Tubing	3

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 1700737




Manufacturer: Daikin Applied	TABLE 4
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	

Building Code: CBC 2016	Seismic Certification Limits:	$S_{DS} = 0.63 g$ $z/h = 1.0$	$F_p/W_p = 1.13$ (Neoprene), 1.42 (Spring)	$I_p = 1.5$
		$S_{DS} = 0.79 g$ $z/h = 0.0$	$F_p/W_p = 0.47$ (Neoprene), 0.59 (Spring)	



Component Type	Manufacturer	Model	Description	Notes	UUT
Control Panel	Siemens	POL687.70/MCQ 208-230V	MicroTech III, 10"x72"x40" (DxWxH)	NEMA 1, Painted Galvanized CS	4
Condenser Fans	Hess Air	HAP-9001132	30" dia, 4 Blades, 33 deg Pitch, 5 lbs	Al Blade/SS Hub	4
Fan Motors	Marathon	5K49ZN6270BS	460V, 3-Phase, 2 HP	CS Housing	4
Condenser Coils	Sanhua	X1470038	Microchannel	Galvanized CS Case, Al Channels	4
Evaporators	Alfa Laval	ZP296KCE	25 HP, Tandem or Trio Config.	CS Shell, Trio Config. Tested	3
		ZP385KCE	30 HP, Tandem or Trio Config.	CS Shell	Interp.
		ZP485KCE	40 HP, Tandem or Trio Config.	CS Shell, Trio Config. Tested	4
		ACH500DQ-94	SS Plate Brazed with Cu		Extrap.
		ACH500DQ-106	SS Plate Brazed with Cu		Extrap.
		ACH500DQ-114	SS Plate Brazed with Cu		Extrap.
		ACH500DQ-134	SS Plate Brazed with Cu		Extrap.
		ACH500DQ-142	SS Plate Brazed with Cu		Extrap.
		ACH500DQ-162	SS Plate Brazed with Cu		Extrap.
		ACH500DQ-182	SS Plate Brazed with Cu		3
		ACH1000DQ-186	SS Plate Brazed with Cu		Interp.
		ACH1000DQ-230	SS Plate Brazed with Cu		4
Expansion Valves	Sporlan	SERI-GS	20 tons Nominal	Brass Bar Body w/ Cu Tubing	Extrap.
		SERI-JS	35 tons Nominal	Brass Bar Body w/ Cu Tubing	Extrap.
		SERI-KS	63 tons Nominal	Brass Bar Body w/ Cu Tubing	4
		SERI-LS	85 tons Nominal	Brass Bar Body w/ Cu Tubing	4

PART NUMBER	REV.	PART DESCRIPTION	RAW MATL DESCRIPTION	RAW MATL PART NO.
334548701	0A	SEISMIC DWG. AGZ 4 FANS		

M1 - M4, ISOLATOR MOUNTING HOLE LOCATIONS ON BOTTOM SURFACE OF UNIT BASE



BLANK PANELS ARE USED ON UNIT SIDES. SLOPED 50° COILS USED ON INSIDE.



CHK	AL.	ENG.	DRW.	DATE	ECO	DESCRIPTION
	ZAM	SNW		02-11-14	C000309027	334547101

REV.	DATE	DESCRIPTION
0A	02/26/2018	SEE SHEET 2

DOC.	AL.	ENG.	DRW.	DATE	ECO	DESCRIPTION

THE CONTENTS OF THIS MATERIAL ARE CONFIDENTIAL AND PROPRIETARY TO DAIKIN APPLIED SOLUTIONS. ANY UNAUTHORIZED USE, REPRODUCTION, DISCLOSURE OR TRANSFER IS STRICTLY PROHIBITED. IF FURNISHED WITH A PROPOSAL, RECIPIENT MAY USE THIS MATERIAL SOLELY TO EVALUATE SUCH PROPOSAL. IF FURNISHED TO AN EXISTING OR POTENTIAL VENDOR, THIS MATERIAL MAY BE USED SOLELY IN PREPARATION OF PROPOSAL OR PERFORMANCE OF WORK FOR DAIKIN APPLIED SOLUTIONS.

DAIKIN APPLIED SOLUTIONS 2013. All rights reserved.

DIMENSIONING AND TOLERANCING CONFORMS TO ASME Y14.5M-1994

TOLERANCE DATA UNLESS OTHERWISE SPECIFIED

SCALE: NONE THIRD ANGLE PROJECTION

FINISH: 125 MICRON INCH ON MACHINED SURFACES

DAIKIN

Page 11 of 20

3345487 D 0A 1 OF 2

OSP-0391-10

UNIT UNDER TEST (UUT) SUMMARY SHEET



TRU PROJECT NO. 1700737

Manufacturer: Daikin Applied	UUT 2
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	
Model Number: AGZ070E Serial Number:	

Product Construction Summary:
Powder coated structural carbon steel skid and frame. See next page for seismic upgrades.

Options/Subcomponent Summary:
460V, controller, condenser fans and motors, condenser coil, scroll compressors, evaporator and expansion valves.

UUT Properties						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
3300	88	94.4	100.4	UUT2a: 3.0 UUT2b: 2.0	UUT2a: 3.0 UUT2b: 1.8	UUT2a: 7.3 UUT2b: 4.3

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016	ICC-ES AC156	2.0	1.0	1.5	3.2	2.4	1.33	0.53	

Test Mounting Details:



UUT2a



UUT2b

UUT2a was base mounted to the shake table interface plate through the skid using 0.75" VMC Maxflex neoprene pads and four 3/4"-diameter Grade 5 bolts. UUT2b was base mounted to the shake table interface plate through the skid using four spring isolators: one VMC Model 825N, two VMC Model 1200N, and one VMC Model 1400. The unit was attached to each spring isolator with one 3/4"-diameter Grade 8 bolt. Each spring isolator was then attached to the shake table interface plate using four 3/4"-diameter Grade 5 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1700737




Manufacturer: Daikin Applied
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers
Model Number: AGZ070E

UUT 2

Serial Number:

Product Construction Summary:



1. Figures 1.a and 1.b show neoprene support blocks added to the interior of the coil sections of UUT2a-b, used to prevent excessive displacement during an earthquake but still allow the coil to expand and contract during normal operation.
2. Figures 2.a through 2.c show corner braces installed on each coil, on the exterior and interior face (16 corner braces total). Brackets were Everbilt 3" heavy duty corner braces, Model 15444, 0.06" thick zinc plated carbon steel with 0.87" flange height.
3. Figures 3.a and 3.b show support channel angle brackets added prior to the shake test (one bracket on each corner). Brackets were Everbilt 2" corner braces, Model 15267, 12 gage galvanized carbon steel, 0.62" wide.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1700737



Manufacturer: Daikin Applied


Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers

Model Number: AGZ070E

Serial Number:

UUT 2




Product Construction Summary:



4. Figures 4.a and 4.b show angle brackets that were installed at each corner of the coil pair, connecting the coil frame to the coil rail (8 brackets total). Brackets were Everbilt 2" corner braces, Model 15267, 12 gage galvanized carbon steel, 0.62" wide.
5. Figures 5.a and 5.b show the stiffener plates added to the base channel at each mounting bolt location. Each stiffener plate was 4"x2.25" with a .875" diameter hole. Each plate was made of pre-painted G60, 10 gauge steel with a nominal thickness of 0.138".

PART NUMBER	REV.	PART DESCRIPTION	RAW MATL DESCRIPTION	RAW MATL PART NO.
334548701	0A	SEISMIC DWG. AGZ 4 FANS		

M1 - M4, ISOLATOR MOUNTING HOLE LOCATIONS ON BOTTOM SURFACE OF UNIT BASE



REV.	DATE	BY	CHKD	DESCRIPTION	REV.	DATE	BY	CHKD	DESCRIPTION
0A	02/26/2018	BDA	ZAM	ADDED CORNER BRACKETS TO COIL THAT WERE REQUIRED AFTER SEISMIC TESTING	0A				

OSP-0391-10

THE CONTENTS OF THIS MATERIAL ARE CONFIDENTIAL AND PROPRIETARY TO DAIKIN APPLIED SOLUTIONS. ANY UNAUTHORIZED USE, REPRODUCTION, DISCLOSURE OR TRANSFER IS STRICTLY PROHIBITED. IF FURNISHED WITH A PROPOSAL, RECIPIENT MAY USE THIS MATERIAL SOLELY TO EVALUATE SUCH PROPOSAL. IF FURNISHED TO AN EXISTING OR POTENTIAL VENDOR, THIS MATERIAL MAY BE USED SOLELY IN PREPARATION OF PROPOSAL OR PERFORMANCE OF WORK FOR DAIKIN APPLIED SOLUTIONS. DAIKIN APPLIED SOLUTIONS 2013. All rights reserved.

DIMENSIONING AND TOLERANCING CONFORMS TO ASME Y14.5M-1994
 TOLERANCE DATA UNLESS OTHERWISE SPECIFIED
 ANGLES = °
 X = ±.
 XX = ±.
 XXX = ±.
 FINISH: 125 MICRONS ON MACHINED SURFACES

DAIKIN
 ALL DIMENSIONS ARE IN DECIMAL INCHES
 SCALE: **1/8" = 1"**
 THIRD ANGLE PROJECTION
Page 19 of 20
 3345487 D 0A 2 OF 2

UNIT UNDER TEST (UUT) SUMMARY SHEET



TRU PROJECT NO. 1700737

Manufacturer: Daikin Applied	UUT 3
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	
Model Number: AGZ130D Serial Number:	

Product Construction Summary:
Powder coated structural carbon steel skid and frame. See next page for seismic upgrades.

Options/Subcomponent Summary:
460V, controller, condenser fans and motors, condenser coil, scroll compressors, evaporator and expansion valves.

UUT Properties						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
6520	88	173.1	100.4	UUT3a: 5.8 UUT3b: 2.8	UUT3a: 4.0 UUT3b: 2.0	UUT3a: 10.8 UUT3b: 4.3

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)	
CBC 2016	ICC-ES AC156	2.0	1.0	1.5	3.2	2.4	1.33	0.53	

Test Mounting Details:



UUT3a



UUT3b

UUT3a was base mounted to the shake table interface plate through the skid using 0.75" VMC Maxflex neoprene pads and six 3/4"-diameter Grade 5 bolts. UUT3b was base mounted to the shake table interface plate through the skid using six spring isolators: two VMC Model 1200N, two VMC Model 1700N, and two VMC Model 2000. The unit was attached to each spring isolator with one 3/4"-diameter Grade 8 bolt. Each spring isolator was then attached to the shake table interface plate using four 3/4"-diameter Grade 5 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1700737



Manufacturer: Daikin Applied
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers
Model Number: AGZ130D

Serial Number:

UUT 3




Product Construction Summary:



1. Figures 1.a and 1.b show the stiffener plates added to the base channel at each mounting bolt location. Each stiffener plate was 4"x2.25" with a .875" diameter hole. Each plate was made of pre-painted G60, 10 gauge steel with a nominal thickness of 0.138".

PART NUMBER	REV.	PART DESCRIPTION	RAW MATL DESCRIPTION	RAW MATL PART NO.
334548703	00	SEISMIC DWG, AGZ 8 FANS		

ISOLATOR MOUNTING HOLE LOCATIONS ON BOTTOM SURFACE OF UNIT BASE



PK	HL	DD	DR	DM	CD	DESIGN SHEET	CAD DWTG ATTACHED TO	REV	REVISION	DATE	ECO	REVISION	DATE	ECO
						331749223								

MASTER

THE CONTENTS OF THIS MATERIAL ARE CONFIDENTIAL AND PROPRIETARY TO DAIKIN APPLIED. ANY UNAUTHORIZED USE, REPRODUCTION, DISCLOSURE OR TRANSFER IS STRICTLY PROHIBITED. IF FURNISHED WITH A PROPOSAL, RECIPIENT MAY USE THIS MATERIAL SOLELY TO EVALUATE SUCH PROPOSAL. IF FURNISHED TO AN EXISTING OR POTENTIAL VENDOR, THIS MATERIAL MAY BE USED SOLELY IN PREPARATION OF PROPOSAL OR PERFORMANCE OF WORK FOR DAIKIN APPLIED. DAIKIN APPLIED 2013. All rights reserved.

DIMENSIONING AND TOLERANCING CONFORMS TO ASME Y14.5M-1994		DAIKIN	
TOLERANCE DATA UNLESS OTHERWISE SPECIFIED		ALL DIMENSIONS ARE IN DECIMAL INCHES	
X = ±	ANGLES =	SCALE	THIRD ANGLE PROJECTION
.XX = ±		NONE	
.XXX = ±			
FINISH: 125 MICRONS ON MACHINED SURFACES		3345487 D 00 2 OF 2	
STANDARD TOLERANCES 735070200		DRAWING NUMBER REV. SHEET	

UNIT UNDER TEST (UUT) SUMMARY SHEET



TRU PROJECT NO. 1700737

Manufacturer: Daikin Applied	UUT 4
Model Line: AGZ Trailblazer Air-Cooled Scroll Compressor Chillers	
Model Number: AGZ241E Serial Number: STNU170800043	

Product Construction Summary:
Powder coated structural carbon steel skid and frame.

Options/Subcomponent Summary:
460V, controller, condenser fans and motors, condenser coil, scroll compressors, evaporator and expansion valves.

<i>UUT Properties</i>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
10150	88	327.4	98.6	2.1	3.2	4.3

<i>UUT Highest Passed Seismic Run Information</i>								
Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016	ICC-ES AC156	0.63	1.0	1.5	1.01	0.76	-	-
		0.79	0.0	1.5	-	-	0.53	0.21

Test Mounting Details:



UUT4 was base mounted to the table fixture using eight spring isolators: (2) SLFADA3560-2-104, (4) SLFADA3560-2-105, and (2) SLFADA3560-2-106. The unit was attached to each spring isolator with one 7/8"-diameter Grade 8 bolt. Each spring isolator was then attached to the fixture using four (4) 3/4"-diameter Grade 8 bolts. The fixture was mounted to the table using (36) 1-1/4"-diameter Grade 8 bolts. Unit maintained structural integrity and remained functional per manufacturer requirement. Contents were included in testing per operating conditions.

