



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

APPLICATION FOR HCAI SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP-0502

HCAI Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Greenheck Fan Corporation

Manufacturer's Technical Representative: Mark Vanderkooy

Mailing Address: 1100 Greenheck Drive, Schofield, WI 54476

Telephone: (715) 841-8538

Email: mark.vanderkooy@greenheck.com

Product Information

Product Name: Exhaust/Smoke Control Fans

Product Model Number(s): QEI-9-300 to QEI-60-300

Product Category: Exhaust/Smoke Control Fans

Product Sub-Category: NA

General Description: Inline mixed flow fans.

Mounting Description: Base mounted or Ceiling suspended with spring isolators.

Tested Seismic Enhancements: None

Applicant Information

Applicant Company Name: TRU Compliance, by Structural Integrity Associates

Contact Person: Daniel Zentner

Mailing Address: 233 SW Wilson Ave, Suite 101, Bend, OR 97702

Telephone: (541) 292-5839

Email: dzentner@structint.com

Title: Program Manager



DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: STRUCTURAL INTEGRITY ASSOCIATES, INC.

Name: LACHEZAR HANDZHIYSKI

California License Number: S6515

Mailing Address: 5215 Hellyer Avenue, Suite 210, San Jose, CA 95138

Telephone: (669) 437-0200

Email: Lhandzhiyski@StructInt.com

Certification Method

☐ GR-63-Core

☒ ICC-ES AC156

☐ IEEE 344

☐ IEEE 693

☐ NEBS 3

☐ Other (Please Specify):

Testing Laboratory


Company Name: ENVIRONMENTAL TESTING LABORATORIES, INC. (ETL)

Contact Person: Jeremy Lange

Mailing Address: 11034 Indian Trail, Dallas TX 75229-3513

Telephone: (972) 247-9657

Email: jeremy@etldallas.com





DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION
OFFICE OF STATEWIDE HOSPITAL PLANNING AND DEVELOPMENT

Seismic Parameters

Design Basis of Equipment or Components (F_p/W_p) = 4.5 (SDS = 2.0g); 2.4 (SDS = 3.2g)

SDS (Design spectral response acceleration at short period, g) = 2.0 ($z/h = 1$); 3.2 ($z/h = 0$)

a_p (Amplification factor) = 2.5

R_p (Response modification factor) = 2

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height ratio factor) = 1 and 0

Natural frequencies (Hz) = See Attachment

Overall dimensions and weight = See Attachment

HCAI Approval (For Office Use Only) - Approval Expires on 04/23/2031

Date: 4/23/2025

Name: Timothy Piland

Title: Senior Structural Engineer

Special Seismic Certification Valid Up to: SDS (g) = See Above

z/h = See Above

Condition of Approval (if applicable):

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 2551654-001, Rev. 0



| Manufacturer: Greenheck Fan Corporation | | | | | | TABLE 1 | |
|---|------------|--------------------------------------|-------|--------|--|----------------|------------|
| Model Line: QEI | | | | | | | |
| Certified Product Construction Summary: UL-705; 300 Construction; Belt Drive, Carbon Steel Shaft; Carbon Steel Housing; Carbon Steel Wheel | | | | | | | |
| Certified Options Summary: Motor Cover, Bolted access door, Copper and nylon extended lube lines, Inlet and outlet guard, Slip fit inlet & outlet, Punched inlet & outlet flanges, Belt guard, Belt tube, Mounting base, 80k and 200k bearings, Ceiling hung with motor in position E, G, or C. | | | | | | | |
| Mounting Configuration: Ceiling mounted - spring vibration isolated Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested. | | | | | | | |
| Building Code: CBC 2022 | | Seismic Certification Limits: | | | $S_{DS}= 2.0\text{ g}\quad z/h=1.0$ $S_{DS}= 3.2\text{ g}\quad z/h=0.0$ | | $I_P= 1.5$ |
| Model Line | Model | Dimensions (in) | | | Weight (lbs.) | Notes | UUT |
| | | Depth | Width | Height | | | |
| QEI | QEI-9-300 | 28.5 | 32.0 | 40.3 | 293 | | Interp. |
| | QEI-12-300 | 30.1 | 32.0 | 40.3 | 305 | | Interp. |
| | QEI-15-300 | 34.0 | 36.5 | 44.9 | 410 | | Interp. |
| | QEI-16-300 | 34.0 | 38.0 | 47.8 | 432 | | Interp. |
| | QEI-18-300 | 39.5 | 41.0 | 51.6 | 628 | | Interp. |
| | QEI-20-300 | 41.5 | 43.0 | 54.3 | 687 | | Interp. |
| | QEI-22-300 | 44.0 | 46.0 | 57.6 | 874 | | Interp. |
| | QEI-24-300 | 49.0 | 49.0 | 64.3 | 1,010 | | 48 |
| | QEI-27-300 | 53.0 | 52.0 | 67.0 | 1,153 | | Interp. |
| | QEI-30-300 | 60.5 | 65.0 | 77.0 | 1,180 | | Interp. |
| | QEI-33-300 | 65.0 | 68.0 | 81.0 | 1,892 | | Interp. |
| | QEI-36-300 | 69.0 | 73.0 | 87.5 | 2,184 | | Interp. |
| | QEI-40-300 | 75.5 | 85.0 | 96.3 | 3,028 | | Interp. |
| | QEI-44-300 | 80.5 | 91.0 | 104.8 | 3,513 | | Interp. |
| | QEI-49-300 | 86.5 | 97.0 | 111.3 | 4,590 | | Interp. |
| | QEI-54-300 | 93.5 | 105.0 | 122.3 | 5,199 | | Interp. |
| | QEI-60-300 | 102.4 | 113.0 | 126.5 | 5,812 | | 63 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 2551654-001, Rev. 0



| Manufacturer: Greenheck Fan Corporation | | | | | | TABLE 2 | |
|--|------------|--------------------------------------|-------|--------|---------------|--|------------|
| Model Line: QEI | | | | | | | |
| Certified Product Construction Summary: UL-705; 300 Construction; Belt Drive, Carbon Steel Shaft; Carbon Steel Housing; Carbon Steel Wheel | | | | | | | |
| Certified Options Summary: Motor Cover, Bolted access door, Copper and nylon extended lube lines, Inlet and outlet guard, Slip fit inlet & outlet, Punched inlet & outlet flanges, Belt guard, Belt tube, Mounting base, 80k and 200k bearings, Base mounted with motor in positions A, G, or C. | | | | | | | |
| Mounting Configuration: Base mounted - spring vibration isolated Note: Installed mounting must be of similar configuration and equivalent strength and stiffness to those tested. | | | | | | | |
| Building Code: CBC 2022 | | Seismic Certification Limits: | | | | $S_{DS}= 2.0\text{ g}$ $z/h=1.0$ $S_{DS}= 3.2\text{ g}$ $z/h=0.0$ | $I_P= 1.5$ |
| Model Line | Model | Dimensions (in) | | | Weight (lbs.) | Notes | UUT |
| | | Depth | Width | Height | | | |
| QEI | QEI-9-300 | 28.5 | 32.0 | 40.3 | 203 | | Interp. |
| | QEI-12-300 | 30.1 | 32.0 | 40.3 | 305 | | Interp. |
| | QEI-15-300 | 34.0 | 36.5 | 44.9 | 410 | | Interp. |
| | QEI-16-300 | 34.0 | 38.0 | 47.8 | 432 | | Interp. |
| | QEI-18-300 | 39.5 | 41.0 | 51.6 | 628 | | Interp. |
| | QEI-20-300 | 41.5 | 43.0 | 54.3 | 687 | | Interp. |
| | QEI-22-300 | 44.0 | 46.0 | 57.6 | 874 | | Interp. |
| | QEI-24-300 | 49.0 | 49.0 | 64.3 | 1,010 | | 47 |
| | QEI-27-300 | 53.0 | 52.0 | 67.0 | 1,153 | | Interp. |
| | QEI-30-300 | 60.5 | 65.0 | 77.0 | 1,180 | | Interp. |
| | QEI-33-300 | 65.0 | 68.0 | 81.0 | 1,892 | | Interp. |
| | QEI-36-300 | 69.0 | 73.0 | 87.5 | 2,184 | | Interp. |
| | QEI-40-300 | 75.5 | 85.0 | 96.3 | 3,028 | | Interp. |
| | QEI-44-300 | 80.5 | 91.0 | 104.8 | 3,513 | | Interp. |
| | QEI-49-300 | 86.5 | 97.0 | 111.3 | 4,590 | | Interp. |
| | QEI-54-300 | 93.5 | 105.0 | 122.3 | 5,199 | | Interp. |
| | QEI-60-300 | 102.4 | 113.0 | 126.5 | 5,812 | | 49 |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 2551654-001, Rev. 0



| Manufacturer: Greenheck Fan Corporation | | Table Description: Motors | | | TABLE 3 | | |
|--|--------------|--------------------------------------|-----------------------------------|--|----------------|--|--|
| Model Line: QEI | | | | | | | |
| Building Code: CBC 2022 | | Seismic Certification Limits: | | $S_{DS} = 2.0\text{ g}$ $z/h = 1.0$ $S_{DS} = 3.2\text{ g}$ $z/h = 0.0$ | $I_P = 1.5$ | | |
| Component Type | Manufacturer | Model | Description | Notes | UUT | | |
| Motor | Baldor | 56T | Fan sizes 9-36; 2 hp; 208-600V | | Interp. | | |
| | | 143T | Fan sizes 9-36; 1.5 hp; 208-600V | | Interp. | | |
| | | 145T | Fan sizes 9-36; 3 hp; 208-600V | | Interp. | | |
| | | 182T | Fan sizes 9-40; 5 hp; 208-600V | | Interp. | | |
| | | 184T | Fan sizes 9-40; 7.5 hp; 208-600V | | Interp. | | |
| | | 213T | Fan sizes 15-44; 10 hp; 208-600V | | Interp. | | |
| | | 215T | Fan sizes 15-54; 15 hp; 208-600V | | Interp. | | |
| | | 254T | Fan sizes 18-60; 20 hp; 208-600V | | Interp. | | |
| | | 256T | Fan sizes 22-60; 25 hp; 208-600V | | Interp. | | |
| | | 284T | Fan sizes 24-60; 30 hp; 208-600V | UUT: 25 hp; 575V | 47, 48 | | |
| | | 286T | Fan sizes 27-60; 40 hp; 208-600V | | Interp. | | |
| | | 324T | Fan sizes 30-60; 50 hp; 208-600V | | Interp. | | |
| | | 326T | Fan sizes 36-60; 60 hp; 208-600V | | Interp. | | |
| | | 364T | Fan sizes 40-60; 75 hp; 208-600V | | Interp. | | |
| | | 365T | Fan sizes 44-60; 100 hp; 208-600V | | Interp. | | |
| | | 404T | Fan sizes 49-60; 100 hp; 208-600V | | Interp. | | |
| | | 405T | Fan sizes 49-60; 100 hp; 208-600V | UUT: 100 hp; 230/460V | 49, 63 | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com


SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 2551654-001, Rev. 0



| Manufacturer: Greenheck Fan Corporation | | Table Description: Fan Wheels | | | | | TABLE 4 | |
|--|-------|--------------------------------------|-------|--|------------------|--------------|----------------|---------|
| Model Line: QEI | | | | | | | | |
| Building Code: CBC 2022 | | Seismic Certification Limits: | | $S_{DS} = 2.0 g \quad z/h = 1.0$ $S_{DS} = 3.2 g \quad z/h = 0.0$ | | $I_P = 1.5$ | | |
| Model Line (Manufacturer) | Model | Dimension (in) | | | Weight (lbs.) | Material | Notes | UUT |
| | | Depth | Width | Height | | | | |
| QEI (Greenheck) | 15 | | 15.0 | | 20 | Carbon Steel | | Interp. |
| | 18.25 | | 18.25 | | 24 | Carbon Steel | | Interp. |
| | 20 | | 20.0 | | 30 | Carbon Steel | | Interp. |
| | 22.25 | | 22.25 | | 37 | Carbon Steel | | Interp. |
| | 24.5 | | 24.5 | | 46 | Carbon Steel | | Interp. |
| | 27 | | 27.0 | | 56 | Carbon Steel | | Interp. |
| | 30 | | 30.0 | | 73 | Carbon Steel | | 47, 48 |
| | 33 | | 33.0 | | 89 | Carbon Steel | | Interp. |
| | 36.5 | | 36.5 | | 135 | Carbon Steel | | Interp. |
| | 40.25 | | 40.25 | | 171 | Carbon Steel | | Interp. |
| | 44.5 | | 44.5 | | 228 | Carbon Steel | | Interp. |
| | 49 | | 49.0 | | 348 | Carbon Steel | | Interp. |
| | 54.25 | | 54.25 | | 421 | Carbon Steel | | Interp. |
| | 60 | | 60.0 | | 515 | Carbon Steel | | Interp. |
| | 66 | | 66.0 | | 630 | Carbon Steel | | Interp. |
| | 73 | | 73.0 | | 780 | Carbon Steel | | 49, 63 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

TRU PROJECT NO. 2551654-001, Rev. 0



UNIT UNDER TEST (UUT) SUMMARY SHEET


TRU PROJECT NO. 2551654-001, Rev. 0



| Manufacturer: Greenheck Fan Corporation | | | | | | | | |
|--|--|---------------------------------|---------------------------------|--------------------|------------------------------|-----------------------|------------|----------------------|
| Model Line: QEI | | | | | | | | |
| UUT | Unit Description (mounting) | Report Number (UUT#) | Testing Lab | Year Tested | ISO 17025 Accredited? | S_{Ds} | z/h | I_p |
| 47 | QEI-24-300 (base mounted - isolated) | 14238, Rev. 1 (UUT47) | Environmental Testing Lab (ETL) | 2016 | Yes | 2.0 3.2 | 1.0 0.0 | 1.5 |
| 48 | QEI-24-300 (ceiling mounted - isolated) | 14238, Rev. 1 (UUT48) | Environmental Testing Lab (ETL) | 2016 | Yes | 2.0 3.2 | 1.0 0.0 | 1.5 |
| 49 | QEI-60-300 (base mounted - isolated) | 14238, Rev. 1 (UUT49) | Environmental Testing Lab (ETL) | 2016 | Yes | 2.0 3.2 | 1.0 0.0 | 1.5 |
| 63 | QEI-60-300 (ceiling mounted - isolated) | 16028-TR-001 (UUT63) | Environmental Testing Lab (ETL) | 2017 | Yes | 2.0 3.2 | 1.0 0.0 | 1.5 |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

BY: Timothy J. Piland

DATE: 04/23/2025



REVIEWED FOR CODE COMPLIANCE

HCAI

OSP-0002

CALIFORNIA BUILDING CODE, 2022

Notes:

TRU PROJECT NO. 2551654-001, Rev. 0



UUT47 was base mounted - isolated to the test fixture using four (4) VMC MSH-1E-530N isolators to the equipment skid using one (1) 1/2" Grade 8 bolt for each isolator. The isolators were mounted to the test fixture using two (2) 5/8" Grade 8 bolts for each isolator. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

TRU PROJECT NO. 2551654-001, Rev. 0



UUT48 was ceiling mounted - isolated to the test fixture using four (4) 5/8" Ø A307 threaded rods w/ rod stiffeners, two (2) Mason RW30N-B-410 & two (2) Mason RW30N-B-336 isolators and four (4) 3/8" Ø cable braces with Mason SCB-3/SCBH-3 clips at ends.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 2551654-001, Rev. 0



| Manufacturer: Greenheck Fan Corporation Model Line: QEI Model Number: QEI-60-300 Serial Number: N/A | | | | | | UUT 49 | | | |
|--|----------------|---------------------|--------|-------------------------------|---|------------------------|------------------------|------------------------|--|
| Test Report: 14238, Rev. 1 (UUT49) | | | | | | | | | |
| UUT Properties | | | | | | | | | |
| Weight (lbs.) | Dimension (in) | | | Lowest Natural Frequency (Hz) | | | | | |
| | Depth | Width | Height | Front-Back | Side-Side | Vertical | | | |
| 5,812 | 102.4 | 113.0 | 126.5 | 2.5 | 2.1 | 4.3 | | | |
| UUT Highest Passed Seismic Run Information | | | | | | | | | |
| Building Code | Test Criteria | S _{DS} (g) | z/h | I _P | A _{FLX-H} (g) | A _{RIG-H} (g) | A _{FLX-V} (g) | A _{RIG-V} (g) | |
| CBC 2022 | ICC-ES AC156 | 2.0 | 1.0 | 1.5 | 3.20 | 2.40 | 2.13 | 0.85 | |
| | | 3.2 | 0.0 | | | | | | |
| Product Construction Summary: | | | | | Test Mounting Details: | | | | |
| UL-705; 300 Construction; Belt Drive, Carbon Steel Shaft; Carbon steel Housing; Carbon Steel Wheel | | | | |  | | | | |
| Options/Subcomponent Summary: | | | | | | | | | |
| Description | | | | | | | | | |
| 100 Hp Motor | | | | | | | | | |
| Motor Cover | | | | | | | | | |
| Bolted Access Door | | | | | | | | | |
| Belt Guard | | | | | | | | | |
| Belt Tube | | | | | | | | | |
| Inlet and Outlet Guard | | | | | | | | | |
| Punched Inlet & Outlet Flanges | | | | | | | | | |
| Copper and Nylon Extended Lube Lines | | | | | | | | | |
| Mounting Base | | | | | | | | | |
| Motor in Position C | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| UUT49 was base mounted - isolated to the test fixture using four (4) Mason SSLFH-C-1750 isolators to the equipment skid using one (1) 1/2" Grade 8 bolt for each isolator. The isolators were mounted to the test fixture using four (4) 5/8" Grade 8 bolts for each isolator. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions. | | | | | | | | | |

TRU PROJECT NO. 2551654-001, Rev. 0

A large, circular, glowing light fixture or fan assembly is mounted within a complex, dark metal framework in an industrial setting. The structure is made of heavy, dark-colored metal beams and cross-braces. The central circular unit has a bright, white, grid-like mesh in the center, surrounded by a glowing ring. The background shows a dimly lit industrial space with various equipment and structural elements.

UUT63 was ceiling mounted - isolated to the test fixture using four (4) 7/8" Ø A307 threaded rods w/ rod stiffeners and four (4) Mason RW30N-D-2150 isolators & sixteen (16) 3/8" Ø cable braces with Mason SCB-4 brackets at ends.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.