

# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

| APPLICATION FOR HCAI SPECIAL SEISMIC  | OFFICE USE ONLY         |
|---|-------------------------|
| CERTIFICATION PREAPPROVAL (OSP)   | APPLICATION #: OSP-0515 |
| HCAI Special Seismic Certification Preapproval (OSP)                        |                         |
| Type: New X Renewal   |                         |
| Manufacturer Information  |                         |
| Manufacturer:ait-deutschland GmbH (KKT Chillers)                            |                         |
| Manufacturer's Technical Representative: Markus Zobler                      |                         |
| Mailing Address: Industriestraße 3, 95359 Kasendorf, Germany                |                         |
| Telephone: +49 9228 99060 Email: markus.zobler@                             | ait-deutschland.eu      |
| Product Information   | MA                      |
| Product Name: Chillers  | 1 A                     |
| Product Type: Chillers - CT Scanners  | 72                      |
| Product Model Number: <u>cBoxX 60 and cBoxX 70</u>                          | Ĩ                       |
| General Description: Chiller systems for cool fluid using air cooled tefrig | gerant.                 |
| Mounting Description: See Certified Product Tables                          |                         |
| Tested Seismic Enhancements: None DATE: 08/12/2022                          | 6                       |
|   | 0                       |
| Applicant Information   | 1 4 m                   |
| Applicant Company Name: W.E. Gundy & Associates, Inc.                       | 001                     |
| Contact Person: Travis Soppe  |                         |
| Mailing Address: 1199 Shoreline Drive Suite 310, Boise, ID 83702            |                         |
| Telephone: (208) 342-5989 Email: tsoppe@wegai.degies                        | com                     |
| Title: President  |                         |

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY





# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

| alifornia Licensed Structural Engineer Responsible for the Engineering and Test Report(s) |
|---|
| ompany Name: W.E. GUNDY & ASOCIATES INC.  |
| ame: Travis Soppe California License Number: S6115  |
| ailing Address: P.O. Box 9121, Boise, ID 83707  |
| elephone: (208) 342-5989 Email: tsoppe@wegai.com  |
|   |
| ertification Method   |
| GR-63-Core X ICC-ES AC156 IEEE 344 IEEE 693 NEBS 3  |
| Other (Please Specify):   |
| FOR CODE CO.  |
| esting Laboratory   |
| ompany Name: IABG TEST LABORATORY   |
| ontact Person: Dr. Steffen Roedling   |
| lailing Address: Einsteinstrasse 20, D-85521 Ottobrunn, Germany                           |
| elephone: +49 89 6088 2052 Email: roedling@iabg.de  |
|   |
| C DATE: 08/12/2022  |
|   |
|   |
| DATE: 08/12/2022  |
| BUILDING  |

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





# DEPARTMENT OF HEALTH CARE ACCESS AND INFORMATION FACILITIES DEVELOPMENT DIVISION

| Seismic Parameters                        |   |
|---|---|
| Design Basis of Equipment or Component    | s (Fp/Wp) = See Attachments   |
| SDS (Design spectral response acce        | eleration at short period, g) = $2.0$ at z/h = 1 and 2.5 at z/h = 0 |
| ap (Amplification factor) =               | See attachments   |
| Rp (Response modification factor) =       | See attachments   |
| $\Omega_0$ (System overstrength factor) = | 2.0   |
| Ip (Importance factor) =                  | 1.5   |
| z/h (Height ratio factor) =               | 1 and 0   |
| Natural frequencies (Hz) =                | See Attachment  |
| Overall dimensions and weight =           | See Attachment  |
|   | NEDFOLID  |
| HCAI Approval (For Office Use Only)       | Approval Expires on 08/12/2028                                      |
| Date: 8/12/2022                           | OSP-0515  |
| Name: Mohammad Karim                      | Title: Supervisor, Health Facilities                                |

iad Nafii

NG CODE

08/1

PNIA BU

z/h =

See Above

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

Special Seismic Certification Valid Up to: SDS (g) = See Above

Condition of Approval (if applicable):

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY

#### KKT Chillers - AIT Deutschland GmbH SPECIAL SEISMIC CERTIFICATION CERTIFIED SYSTEM AND COMPONENTS



Manufacturer: KKT Chillers - AIT Deutschland GmbH

#### System: KKT Compact Chillers

| Sustan Component                 | KKT Chillers   | Diı          | mensions (i   | in)        | Weight              | Mounting          | UUT   |
|----------------------------------|--|--------------|---------------|------------|---------------------|-------------------|-------|
| System Component                 | ID Number <sup>3</sup>   | Width        | Length        | Height     | (lb)                | Mounting          |       |
| cBoxX 60 Chiller                 | 909060-00244<br>909060-00244z<br>909060-00424<br>909060-00424z | 79.9         | 48.8          | 32.7       | 1,300 <sup>2)</sup> | flexible<br>floor | UUT-1 |
| cBoxX 70 Chiller                 | 909070-00249<br>909070-00249z<br>909070-00425<br>909070-00425z | F 79.9CC     | D72.40        | 32.7<br>MB | 1,620 <sup>2)</sup> | flexible<br>floor | UUT-2 |
| Chiller Interface Panel<br>(CIP) | 909000.0072  | 43.3         | 24.0          | 13.6       | 120                 | rigid wall        | UUT-3 |
| Remote Control Panel<br>(RCP)    | 909 <mark>000</mark> .0071                                     | OSP-<br>11.8 | -0515<br>12.0 | 4.7        | 11                  | rigid wall        | UUT-4 |

<sup>1)</sup> All components are manufactured by AIT Deutschland GmbH unless noted otherwise. The part numbers listed uniquely identify the type of component, manufacturer, and material of construction for each sub-component within the tested units.

<sup>2)</sup> Weight includes normal operating fluid used during seismic test. 2022

<sup>3)</sup> The identified chillers each have two internal KKT identification numbers that are used for marketing and an additional z designation for identifying different cooling liquids (same density of tested cooling liquid). The chillers listed with the two identification numbers and additional z designations are identical in design and construction.

VIA BUILDING

| SEISMIC CERTIFICATION LIMITS |      |                     |       |                |                |                |                |   |      |
|------------------------------|------|---------------------|-------|----------------|----------------|----------------|----------------|---|------|
| System Component             | Code | S <sub>DS</sub> (g) | z / h | I <sub>P</sub> | a <sub>P</sub> | R <sub>P</sub> | Ω <sub>0</sub> | $\mathbf{F}_{\mathbf{P}}$ / $\mathbf{W}_{\mathbf{P}}$ |      |
| cBoxX 60 Chiller             | CBC  | 2.0                 | 1.0   | 1.50           | 2.5            | 2.5            | 2.0            | 3.60  |      |
|                              | 2019 | 2.5                 | 0     |                |                |                |                | 1.50  |      |
| cBoxX 70 Chiller             | CBC  | 2.0                 | 1.0   | 1.50           | 2.5            | 2.5            | 2.0            | 3.60  |      |
|                              | 2019 | 2.5                 | 0     |                |                |                |                | 1.50  |      |
| Chiller Interface Panel      | CBC  | 2.0                 | 1.0   | 1.50           | 2.5            | 6.0            | 2.0            | 1.50  |      |
| (CIP)                        | 2019 | 2.5                 | 0     |                |                |                |                | 1.13  |      |
| Remote Control Panel         | CBC  | 2.0                 | 1.0   | 1.50           | 1.50 2         | 2.5            | 6.0            | 2.0   | 1.50 |
| (RCP)                        | 2019 | 2.5                 | 0     |                | 2.5            | 0.0            | 2.0            | 1.13  |      |
| 08/12/2022                   |      | OSP-0515            |       |                |                |                | Page           | 4 of 8  |      |

# UNIT UNDER TEST (UUT) SUMMARY SHEET



**Mounting Details:** Flexible floor mounted on 4 - AMC Mecanocaucho Marinelager S/N:136024 isolation divices. Each isolator connects to the UUT with one M16 Grade 8.8 bolt and mounts to the table with 2 - M12 Grade 8.8 bolts.

| ANLAGEN   Manufacture  | r: KKT Chillers -                                   | AIT Deutso          | E 087        | bH             |                |                  |                | 2              |
|--|---|---------------------|--------------|----------------|----------------|------------------|----------------|----------------|
| _  | Compact Chiller c                                   |                     |              |                | mber: 909      | 060-00244        |                |                |
|  | n: Cools liquids us                                 | -                   |              | 7-11:          |                | <b></b>          |                |                |
|  | tion: KKT Compa                                     |                     | vith 66kW    | net cooli      | ng capacity    | . Unit is flo    | oor mounte     | d on           |
| vibration isolators as detailed above.Test Location: IABG mbH, GermanyTest Date: November 2016 |   |                     |              |                |                |                  |                |                |
| 1 cst Location   |   | -                   | UUT PRO      | DEDTIE         |                | • 110 venibe     | 1 2010         |                |
| <br>   |   |                     |              |                | Ø              |                  | 1 E -          | (II-)          |
| Weight (lb)*   | Width   | Dimensions (inches) |              |                |                | Natural Fequency |                |                |
| 1,300  | Width<br>79.9                                       | Depth<br>48.8       |              | Height<br>32.7 |                | FB<br>4.2        | SS<br>3.0      | V<br>9.4       |
|  | normal operating flui                               |                     | .0           | 3              | 1              | 4.2              | 5.0            | 7.4            |
| weight menudes   | normai operating flui                               |                     |              |                |                |                  |                |                |
|  |   | SEISM               | IC TEST      | PARAM          | ETERS          |                  |                |                |
| Building Co  | de / Test Criteria                                  | $S_{DS}(g)$         | z / h        | Ip             | $A_{FLX-H}(g)$ | $A_{RIG-H}(g)$   | $A_{FLX-V}(g)$ | $A_{RIG-V}(g)$ |
| CBC 2019 /   | ICC-ES AC156  | 2.00<br>2.50        | 1.0<br>0.0   | 1.5<br>1.5     | 3.20           | 2.40             | 1.67           | 0.67           |
|  | as full of contents dur<br>tural integrity during a | ing testing an      | d remained f | uctional be    | fore and after | the ICC-ES       |                |                |

# UNIT UNDER TEST (UUT) SUMMARY SHEET



**Mounting Details:** Flexible floor mounted on 4 - AMC Mecanocaucho Marinelager S/N:136024 isolation divices. Each isolator connects to the UUT with one M16 Grade 8.8 bolt and mounts to the table with 2 - M12 Grade 8.8 bolts.



# UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with 3 - M8 Grade 8.8 bolts



# UNIT UNDER TEST (UUT) SUMMARY SHEET



Mounting Details: Rigid wall mounted with 4 - M8 Grade 8.8 bolts

