



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY
APPLICATION #: OSP - 0566 - 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: [X] New [ ] Renewal

Manufacturer Information

Manufacturer: Vertiv Corporation
Manufacturer's Technical Representative: Ron Spangler
Mailing Address: 1050 Dearborn Dr., Columbus, OH 43085
Telephone: 614-841-7993 Email: Ron.Spangler@VertivCo.com

Product Information

Product Name: Vertiv SRC
Product Type: Split Air Conditioning Units
Product Model Number: SRC18, SRC24, SRC36
General Description: Indoor and outdoor split cooling system
Mounting Description: Base Mounted - Rigid and Wall Mounted- Rigid

Applicant Information

Applicant Company Name: TRU Compliance by Structural Integrity Associates, Inc.
Contact Person: Andrew M. Coughlin, SE
Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138
Telephone: 844-878-0200 Email: acoughlin@structint.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant: [Handwritten Signature] Date: 3/28/2018
Title: Director, TRU Compliance Company Name: Structural Integrity Associates, Inc.

\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: TRU Compliance by Structural Integrity Associates, Inc.

Name: Andrew M. Coughlin California License Number: S6082

Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138

Telephone: 844-878-0200 Email: [acoughlin@structint.com](mailto:acoughlin@structint.com)

**Supports and Attachments Preapproval**


Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)

Supports and attachments are not preapproved

**Certification Method**

Testing in accordance with:  ICC-ES AC156

Other (Please Specify): \_\_\_\_\_




**Testing Laboratory**

Company Name: QualTech NP by Curtiss-Wright

Contact Name: Jason VonNida

Mailing Address: 4600 East Tech Drive

Telephone: 513-201-2139 Email: [jvonnida@curtisswright.com](mailto:jvonnida@curtisswright.com)





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: [X] Yes [ ] No

Design Basis of Equipment or Components (Fp/Wp) = 1.57 (SDS = 2.09); 1.46 (SDS = 3.25)

SDS (Design spectral response acceleration at short period, g) = 2.09 (z/h = 1); 3.25 (z/h = 0)

ap (In-structure equipment or component amplification factor) = 2.5

Rp (Equipment or component response modification factor) = 6.0

Omega\_0 (System overstrength factor) = 2.0

Ip (Importance factor) = 1.5

z/h (Height factor ratio) = 1 (SDS = 2.09); 0 (SDS = 3.25)

Equipment or Component Natural Frequencies (Hz) =

Overall dimensions and weight (or range thereof) =

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: [ ] Yes [X] No

Design Basis of Equipment or Components (V/W) =

SDS (Design spectral response acceleration at short period, g) =

SD1 (Design spectral response acceleration at 1 second period, g) =

R (Response modification coefficient) = OSP-0566-10

Omega\_0 (System overstrength factor) =

Cd (Deflection amplification factor) = BY:Ali Sumer

Ip (Importance factor) = 1.5

Height to Center of Gravity above base = DATE: 03/05/2019

Equipment or Component Natural Frequencies (Hz) =

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2015: [ ] Yes [X] No

List of Attachments Supporting Special Seismic Certification

[X] Test Report(s) [ ] Drawings [ ] Calculations [X] Manufacturer's Catalog

[X] Other(s) (Please Specify): Product Matrices and Four Point Letter

OSHPD Approval (For Office Use Only) - Approval Expires on December 31, 2022

Signature: [Handwritten Signature]

Date: March 5, 2019

Print Name: Ali Sumer

Title: DSE

Special Seismic Certification Valid Up to : SDS (g) = See Above

z/h = See Above

Condition of Approval (if applicable):






# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 1701334



<b>Manufacturer:</b>	Liebert Corporation	<b>TABLE 1</b>
<b>Model Line:</b>	Liebert SRC	

Nomenclature: Liebert SRC Split System  
FOR REFERENCE ONLY









# UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1701334



<b>Manufacturer:</b> Liebert Corporation	<b>UUT 30</b>
<b>Model Line:</b> Liebert SRC	
<b>Model Number:</b> SRC36HPC000	
<b>Serial Number:</b> 710KASL0GY66	

**Product Construction Summary:**  
Carbon steel housing

**Options/Subcomponent Summary:**

<i>UUT Properties</i>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
124	37.5	13	32	9.92	14.72	30.85

<i>UUT Highest Passed Seismic Run Information</i>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016	ICC-ES AC156	2.09	1.0	1.5	3.34	2.51	2.17	0.87	
		3.25	0.0	1.5					

**Test Mounting Details:**



Unit mounted to the shake table with four (4) 3/8"-16 Grade 5 hex bolts with 3/8" lock washer and 3/8" flat washer. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.



# UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1701334



<b>Manufacturer:</b> Liebert Corporation	<b>UUT 32</b>
<b>Model Line:</b> Liebert SRC	
<b>Model Number:</b> SRC36HPN000	
<b>Serial Number:</b> 710KAXU0HB34	

**Product Construction Summary:**  
Carbon steel housing with plastic cover and steel mounting bracket.

**Options/Subcomponent Summary:**

<b>UUT Properties</b>						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
41	10.5	45.5	14	N/A	N/A	N/A

<b>UUT Highest Passed Seismic Run Information</b>									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016	ICC-ES AC156	2.09	1.0	1.5	3.34	2.51	2.17	0.87	
		3.25	0.0	1.5					

**Test Mounting Details:**



Wall mount plate was fastened to wall fixture using eight (8) #10 self-tapping screws. UUT hangs on the wall mount plate and snaps into the wall mount plate.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.